

IEC**IECEE**

®

™

Ref. Certif. No.

CN54730

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Fuse switch disconnecter

Name and address of the applicant

ABB Oy
Muottitie 2A FI-65320 VAASA, Finland

Name and address of the manufacturer

ABB Oy
Muottitie 2A FI-65320 VAASA, Finland

Name and address of the factory

ABB Bulgaria EOOD – Rakovski branch
BULGARIA, 4142 Village of Stryama, Region of Plovdiv,
Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial
Road 1, nr,14-18

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp: 8kV;Ui: 1000V;Ith: 250A(400V,500V,690V),200A (800V), 250A (1000V); AC-21B:
Ue/Ie: 690V/250A; AC-22B: Ue/Ie: 500V/250A; AC-23B: Ue/Ie: 400V/250A; AC-22B:
Ue/Ie: 800V/200A; AC-22B: Ue/Ie: 1000V/250A; Iq: 100kA(400V,500V,690V, 800V), 120
kA(1000V); 50/60Hz;IP30(front);3P

Trademark / Brand (if any)

ABB

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

ZLBM1, ZHBM1;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020;IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-098874

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Sep.15,2021

Signature:

谢肇旭

Xie ZhaoXu

CB 0064355