

ABB Automation & Power World: April 18-21, 2011

WPS-131-1

Reliability Based Transmission System Planning

WPS-131-1

Reliability Based Transmission System Planning

- Speaker name: Bob Reymers
- Speaker title: Project Development Manager
- Company name: ABB Turnkey Substation Group
- Location: Raleigh, NC

Co-presenter

- Speaker name: Krassimir Kutlev
- Speaker title: Consultant
- Company name: ABB Consulting Group
- Location: Raleigh, NC

Your safety is important to us



Please be aware of these emergency procedures

- In the event of an emergency please dial ext. 55555 from any house phone. Do not dial 9-1-1.
- In the event of an alarm, please proceed carefully to the nearest exit. Emergency exits are clearly marked throughout the hotel and convention center.
- Use the stairwells to evacuate the building and do not attempt to use the elevators.
- Hotel associates will be located throughout the public space to assist in directing guests toward the closest exit.
- Any guest requiring assistance during an evacuation should dial “0” from any house phone and notify the operator of their location.
- Do not re-enter the building until advised by hotel personnel or an “all clear” announcement is made.

Your safety is important to us

Convention Center exits in case of an emergency

You are here



Know your surroundings:

- Identify the meeting room your workshop is being held in
- Locate the nearest exit

Agenda

- Project Objective
- Project Tasks
- Project Results
- Next Steps

Project Objective

- Model a selected subsystem of the utility sub-transmission system
- Confirm that subsystem reliability could be determined and dollarized
- Confirm that impact on reliability of various investment alternatives can be quantified.


Project Tasks

- Task 1 - Network Selection and Options Identification
- Task 2 – Network Modeling
- Task 3 – Model Benchmarking with Utility Data
- Task 4 – Performance of Reliability Analysis
- Task 5 – Investment Option Assessments

Task One – Selection of Network and Options

- Network Selection
 - Network Selected
- Investment Option Selection
 - No Predetermined Options Identified
 - Options Identified Based on Model Output
- Obtained Data Needed for Model Benchmarking

VS 60 kV System




Task Two – Selection of ETAP

- Publicly Available Software
- Models Networks and Substations
- Uses Industry (CIGRE, CEA, IEEE) and/or Customer Specific Reliability Data
- Determines Failure Rates at All Modeled Points
- Calculates Reliability Indices
 - System Level – SAIFI, SAIDI, EENS, ECOST, etc.
 - Load Level – Outage Frequency, Outage Durations, EENS, ECOST etc.
- Cost Competitive
- Widely Used and Supported

Reliability Results – System Related

- PUC Focused:
 - SAIFI - System Average Interruption Frequency Index
 - Average Number of Interruptions per Customer per Year
 - SAIDI - System Average Interruption Duration Index
 - Average Interruption Duration per Customer per Year
 - CAIDI - Customer Average Interruption Duration Index
 - Average Hours per Interruption
- Shareholder Focused:
 - EENS - System Expected Energy Not Supplied Index
 - Megawatt Hours per Year
- Customer Focused:
 - ECOST - System Expected Interruption Cost
 - Customer Interruption Costs per Year (IEEE or Utility Specific)

ETAP Model of VS System



Task Three - Model Benchmarking

- Data Needed for Benchmarking
 - Single Line Diagrams (SLD's)
 - Substation Equipment Data (Age, Type)
 - Overhead Lines
 - Loads/Feeders information
 - Current Utility System Reliability Indices
- Reliability Data Needed
 - Failure Rates for Substation Components and Overhead Lines
 - Component Outage Records, System Outage Records
 - Mean Time to Replace or Repair, Mean Time to Switch, Maintenance Frequency
- Iterations Performed to Match Existing System Reliability Indices

Reliability Model Benchmarking Iterations

1. First Iteration

- Preliminary Configuration for VS with OHL Outages
- All Interruptions for One Minute and Over Considered

2. Second Iteration

- 60 kV OHL Line Lengths Corrected
- 60 kV OHL Outages with Durations Between 1 to 3 Minutes Eliminated
- Back Up Power Supply for VS System Considered

3. Third Iteration

- Prorated Failure Rate Based on Circuit Breaker Age
- Failure Rate Based on Transformer Age (No Correlation Noted, Change Deleted)
- MTTS Corrected Based on SCADA Availability
- Remove the Spare Transformer for LND
- MTT Replace for Transformers Changed to 120 Hours
- MTT Replace for Breakers and Switches Changed to 80 Hours
- MTTR for Breakers Changed to 12 Hours
- Obtained Information About Installation Date of CB 12 at WP Sub

4. Fourth Iteration

- Increase MTTR for Equipment According to Industry Standards
- Breakers (24 Hours), Transformers (120/40 Hours for 3/1PH), Switches (16 Hours)

5. Fifth Iteration

- Disconnect WP Generation Sub from the rest of the system
- Decrease MTTR for Transformers back to 72 hr for 3 phases and 24 hr for 1 phase; LTC - 24 hr
- Decrease MTTR for CB to 20 hr for 60 kV & 22 hr for 230 kV
- Decrease MTTR for switches to 12 hr - 60 kV and to 14 hr - 230 kV

Task Four – Performance of Reliability Analysis

- Load Point Related
 - Reliability Indices at Any Load Point on Single Line Diagram
- System Related - Impact on EENS and ECOST
 - For Entire System
 - Ranking Components Contribution
 - Ranking Substation Contribution – VS, PG, etc.
 - Ranking Components Types Contribution – OHL, transformers, circuit breakers, etc.
 - High Impact Loads - Loads Feeding Selected Customers, e.g., PG Sub
 - Ranking Components Contribution to the High Impact Loads

Task Four – Opportunities for Investment

- “Locational” Impacts on EENS and ECOST
 - Sort by System Location
 - Sum for All Components in Specific Location
 - E.g., PG Substation
 - Look for High Impact Locations
- Component Impacts on EENS and ECOST
 - Sort by System Component
 - E.g. all transformers > x Years old
 - E.g. all Oil Circuit Breakers
 - Look for High Impact Component Groups

Impact Sorted by System Component

EENS (MWhrs/year)

1	T1_VS	Xfmr2	222.035
2	Main Bus+2A+2CT VS	Bus	102.422
3	Line VS_EL	Line	101.007
4	T2_VS	Xfmr2	74.012
5	Bus+4A+2CT 60kV_TrstrVS	Bus	47.641
6	Line EL_PG_JCT	Line	37.387
7	CB32+2CT	PD	20.804
8	Line PG Jct_WP	Line	19.253
9	T1 MRT	Xfmr2	18.982
10	T1 LND	Xfmr2	17.112
11	T1 MRM	Xfmr2	16.267
12	Line PG Tap	Line	15.217
13	T1 CL	Xfmr2	13.811
14	T1_EL	Xfmr2	12.855
15	T1_CRL	Xfmr2	12.394
16	CB42+2CT	PD	11.281
17	T2 PG	Xfmr2	11.113
18	SW 41	PD	11.073
19	SW 11	PD	11.073
20	SW 61	PD	11.073
21	SW 71	PD	11.073
22	SW 73	PD	11.073
23	SW 77	PD	11.073
24	SW 21	PD	11.073
25	SW 51	PD	11.073
26	SW 31	PD	11.073
27	T1 PG	Xfmr2	10.036
28	T1 CC	Xfmr2	9.640
29	Bus VS MAIN	Bus	9.324
30	T1 IN	Xfmr2	8.572

ECOST (\$/Year)

1	T1_VS	Xfmr2	1,140,231
2	Main Bus+2A+2CT VS	Bus	496,184
3	Line VS_EL	Line	406,235
4	T2_VS	Xfmr2	371,467
5	Bus+4A+2CT 60kV_TrstrVS	Bus	230,800
6	Line EL_PG_JCT	Line	143,847
7	T1 MRT	Xfmr2	118,711
8	CB32+2CT	PD	92,720
9	T1 CL	Xfmr2	85,518
10	T1 MRM	Xfmr2	66,695
11	T1_EL	Xfmr2	66,167
12	T1 IN	Xfmr2	63,290
13	Line PG Tap	Line	61,442
14	Line PG Jct_WP	Line	60,652
15	T1 PG	Xfmr2	60,523
16	SW 71	PD	52,675
17	SW 73	PD	52,675
18	SW 61	PD	52,675
19	SW 11	PD	52,675
20	SW 31	PD	52,675
21	SW 41	PD	52,675
22	SW 51	PD	52,675
23	SW 77	PD	52,675
24	SW 21	PD	52,675
25	T2 PG	Xfmr2	47,649
26	T1 CC	Xfmr2	46,589
27	Bus VS MAIN	Bus	44,358
28	T1 LND	Xfmr2	40,445
29	T1_CRL	Xfmr2	39,017
30	T Spare MRT	Xfmr2	38,713

Impact Sorted by Location

EENS (MWhrs/year)

1	VS	638.626
2	OHL	196.920
3	OHL Switches	36.939
4	MRT	35.366
5	PG	28.903
6	MRM	28.405
7	CRL	28.179
8	CL	25.285
9	LND	24.711
10	EL	19.658
11	IN	12.195
12	CC	11.743
13	OLT	11.062
14	NB	7.718
15	WP	4.815


ECOST (\$/year)

1	VS	3,084,866
2	OHL	795,402
3	MRT	216,690
4	OHL Switches	155,780
5	PG	143,129
6	CL	141,889
7	MRM	104,470
8	EL	97,144
9	IN	87,026
10	CRL	86,303
11	LND	61,244
12	CC	55,665
13	OLT	53,929
14	NB	42,400
15	WP	15,160

Task 5 – Investment Option Assessments


- **Alternative 1** - New 60kV OHL between VS & PG Substations
- **Alternative 2** - New 60 kV OHL from MRT Substation to PG Substation
- **Alternative 3** - New 230 kV OHL from TC Substation to PG Jct., with New 230/60 kV Substation
- **Alternative 4** – Upgraded VS Substation

Alternative 1 – New VS – PG OHL



New 15 mile 60 kV OHL Connecting VS Sub with PG Sub
Additional Circuit Breaker Bay in VS Sub

Alternative 1 - New VS – PG OHL



PG 60 kV Switchyard Rebuilt from Collector Bus to Ring Bus

Alternative 1 – Reliability Results at PG, WP, EL

- All additional equipment are considered new – Open Sources & Benchmarked reliability data
- The new OHL can supply loads for PG, WP & EL Substations

Bus/Load	Load Sector	W/ New OHL VS-PG		W/o New OHL VS-PG	
		Average	Annual	Average	Annual
		Interrupting	Outage	Interrupting	Outage
		Rate	Duration	Rate	Duration
ID		f / yr	hr / yr	f / yr	hr / yr
Bus PG1101	N/A	0.5951	7.37	1.7447	16.43
Bus PG1102	N/A	0.5984	7.45	1.7494	16.52
Bus WP1101	N/A	1.7550	10.76	1.7508	16.18
Bus WP1103	N/A	1.7536	10.76	1.7494	16.18
Bus EL1101	N/A	1.7536	10.15	1.7494	13.85
Bus EL1102	N/A	1.7536	10.15	1.7494	13.85


Alternative 1 – PG 12 kV buses ECOST

With New OHL from VS to PG							Without direct OHL from VS to PG					
No	Contributing Element		ECOST	Contributing Element		ECOST	Contributing Element		ECOST	Contributing Element		ECOST
	ID	Type	\$ / yr	ID	Type	\$ / yr	ID	Type	\$ / yr	ID	Type	\$ / yr
1	Bus PG1101		254,166	Bus PG1102		191,864	Bus PG1101		546,381	Bus PG1102		400,433
2	T1_VS	Xfmr2	65,505	T1_VS	Xfmr2	51,363	Line VS_EL	Line	124,966	Line VS_EL	Line	89,736
3	Main Bus+2A+2CT VS	Bus	48,472	Main Bus+2A+2CT VS	Bus	36,959	T1_VS	Xfmr2	65,505	T1_VS	Xfmr2	51,363
4	T1PG	Xfmr2	36,105	T2 PG	Xfmr2	28,310	Line EL_PG JCT	Line	59,836	Line EL_PG JCT	Line	42,967
5	Bus+4A+2CT 60kV_TrnsfrVS	Bus	22,547	Bus+4A+2CT 60kV_TrnsfrVS	Bus	17,192	Main Bus+2A+2CT VS	Bus	48,472	Main Bus+2A+2CT VS	Bus	36,959
6	T2_VS	Xfmr2	21,205	T2_VS	Xfmr2	16,278	T1PG	Xfmr2	36,105	T2 PG	Xfmr2	28,310
7	Bus VS MAIN	Bus	4,353	Bus VS MAIN	Bus	3,285	Line PG Tap	Line	31,069	Line PG Tap	Line	22,310
8	SW 71	PD	3,789	SW 71	PD	2,807	Bus+4A+2CT 60kV_TrnsfrVS	Bus	22,547	Bus+4A+2CT 60kV_TrnsfrVS	Bus	17,192
9	SW 73	PD	3,789	SW 73	PD	2,807	T2_VS	Xfmr2	21,205	T2_VS	Xfmr2	16,278
10	SW 61	PD	3,789	SW 61	PD	2,807	CB32+2CT	PD	20,065	CB32+2CT	PD	15,299
11	SW 11	PD	3,789	SW 11	PD	2,807	Line PG Jct_WP	Line	13,282	Line PG Jct_WP	Line	6,483
12	SW 31	PD	3,789	SW 31	PD	2,807	Bus VS MAIN	Bus	4,353	Bus VS MAIN	Bus	3,285
13	SW 41	PD	3,789	SW 41	PD	2,807	SW 71	PD	3,789	SW 71	PD	2,807
14	SW 51	PD	3,789	SW 51	PD	2,807	SW 73	PD	3,789	SW 73	PD	2,807
15	SW 77	PD	3,789	SW 77	PD	2,807	SW 61	PD	3,789	SW 61	PD	2,807
16	SW 21	PD	3,789	SW 21	PD	2,807	SW 11	PD	3,789	SW 11	PD	2,807
17	CB 422	PD	2,963	LTC PG2	PD	2,115	SW 45_E	PD	3,789	SW 45_E	PD	2,807
18	CB 442	PD	2,963	CB 422	PD	1,446	SW 85_PG	PD	3,789	SW PG2	PD	2,807
19	CB72+2CT	PD	1,785	CB 442	PD	1,446	SW PG1	PD	3,789	SW 85_PG	PD	2,807
20	CB62+2CT	PD	1,785	CB72+2CT	PD	871	SW 75_PG	PD	3,789	SW 75_PG	PD	2,807
21	CB12+2CT	PD	1,785	CB62+2CT	PD	871	SW 31	PD	3,789	SW 31	PD	2,807
22	CB32+2CT	PD	1,785	CB12+2CT	PD	871	SW 33	PD	3,789	SW 33	PD	2,807
23	CB42+2CT	PD	1,785	CB32+2CT	PD	871	SW 41	PD	3,789	SW 41	PD	2,807
24	CB52+2CT	PD	1,472	CB42+2CT	PD	871	SW 51	PD	3,789	SW 51	PD	2,807
25	CB22+2CT	PD	1,472	CB52+2CT	PD	719	SW 77	PD	3,789	SW 77	PD	2,807
26	SW62	PD	638	CB22+2CT	PD	719	SW 21	PD	3,789	SW 21	PD	2,807
27	CCPD 442_O	Bus	423	SW62	PD	473	SW 27 WP Tap	PD	3,789	SW 27 WP Tap	PD	2,807
28	CCPD 422_O	Bus	423	SWPG22	PD	289	SW 25 PG Tap	PD	3,789	SW 25 PG Tap	PD	2,807
29	CBPG3	PD	417	SWPG42	PD	289	SW 29	PD	3,789	SW 29	PD	2,807
30	CBPG1	PD	417	CCPD 442_O	Bus	207	SW 47	PD	3,789	SW 47	PD	2,807
31	CB28	PD	417	CCPD 422_O	Bus	207	SW 49	PD	3,789	SW 49	PD	2,807
32	SWPG31	PD	406	CBPG4	PD	204	SW 27	PD	3,789	SW 27	PD	2,807
33	SWPG11	PD	406	CBPG2	PD	204	CB 422	PD	2,963	LTC PG2	PD	2,115
34	LTC_VS	Bus	202	CB28	PD	204	CB 442	PD	2,963	CB 422	PD	1,446
35	SW 421	PD	141	SW 421	PD	106	CB72+2CT	PD	1,785	CB 442	PD	1,446
36	SW 441	PD	141	SW 441	PD	106	CB62+2CT	PD	1,785	PT 32	Bus	980
37	CTPG31	Bus	25	LTC_VS	Bus	99	CB12+2CT	PD	1,785	CB72+2CT	PD	871
38	CTPG11	Bus	25	CTPG42	Bus	12	CB42+2CT	PD	1,785	CB62+2CT	PD	871
39			254,166	CTPG22	Bus	12	PT 32	Bus	1,475	CB12+2CT	PD	871
						191,864	CB52+2CT	PD	1,472	CB42+2CT	PD	871
							CB22+2CT	PD	1,472	SACT_PG2	Bus	803
							CB 12_WP	PD	1,300	CB52+2CT	PD	719

Alternative 1 – VS System ECOST


With New OHL from VS to PG				Without New OHL from VS to PG			
Contributing Element			ECOST	Contributing Element			ECOST
No	ID	Type	\$ / yr	ID	Type	\$ / yr	
	System		3,851,445	System		3,929,803	
1	T1 VS	Xfmr2	678,972	T1 VS	Xfmr2	678,972	
2	Line VS_PG_New	Line	561,098	Main Bus+2A+2CT VS	Bus	496,184	
3	Main Bus+2A+2CT VS	Bus	496,184	Line VS_EL	Line	406,235	
4	Bus+4A+2CT 60kV_TrnsfrVS	Bus	230,800	Bus+4A+2CT 60kV_TrnsfrVS	Bus	230,800	
5	T2 VS	Xfmr2	217,714	T2 VS	Xfmr2	217,714	
6	T1 MRT	Xfmr2	70,712	Line EL_PG JCT	Line	143,847	
7	Line EL_PG JCT	Line	66,196	CB32+2CT	PD	78,164	
8	T1 CL	Xfmr2	51,018	T1 MRT	Xfmr2	70,712	
9	Line PG Tap	Line	47,619	Line PG Tap	Line	61,442	
10	Bus VS MAIN	Bus	44,358	Line PG Jct_WP	Line	60,652	
11	Line PG Jct_WP	Line	40,886	T1 CL	Xfmr2	51,018	
12	T1 MRM	Xfmr2	39,800	Bus VS MAIN	Bus	44,358	
13	T1_EL	Xfmr2	39,381	T1 MRM	Xfmr2	39,800	
14	T1 IN	Xfmr2	38,382	T1_EL	Xfmr2	39,381	
15	SW 77	PD	38,299	T1 IN	Xfmr2	38,382	
16	SW 51	PD	38,299	SW 71	PD	38,299	
17	SW 21	PD	38,299	SW 73	PD	38,299	
18	SW 73	PD	38,299	SW 61	PD	38,299	
19	SW 71	PD	38,299	SW 11	PD	38,299	
20	SW 41	PD	38,299	SW 31	PD	38,299	
21	SW 61	PD	38,299	SW 41	PD	38,299	
22	SW 11	PD	38,299	SW 51	PD	38,299	
23	SW 31	PD	38,299	SW 77	PD	38,299	
24	T1 PG	Xfmr2	36,105	SW 21	PD	38,299	
25	CB42+2CT	PD	33,283	T1 PG	Xfmr2	36,105	
26	CB52+2CT	PD	31,384	CB42+2CT	PD	33,283	
27	Line IN Tab_IN Sub	Line	29,502	CB52+2CT	PD	31,384	
28	T2 PG	Xfmr2	28,310	Line IN Tab_IN Sub	Line	29,502	
29	T1 CC	Xfmr2	27,719	T2 PG	Xfmr2	28,310	
30	Line VS_PRD Sw's	Line	27,291	T1 CC	Xfmr2	27,719	

Alternative 2 – New MRT – PG OHL




New 10 mile 60 kV OHL from MRT Sub to PG Sub

Alternative 2 – Upgraded PG Substation



PG 60 kV Switchyard Rebuilt to Ring Bus



MRT 60kV Switchyard Rebuilt to Ring Bus

Alternative 2 – Reliability Results

		W/ New OHL MRL-PG		W/o New OHL MRL-PG	
Bus/Load	Load Sector	Average	Annual	Average	Annual
		Interrupting	Outage	Interrupting	Outage
		Rate	Duration	Rate	Duration
ID		f / yr	hr / yr	f / yr	hr / yr
Bus PG1101	N/A	0.5867	7.34	1.7447	16.43
Bus PG1102	N/A	0.5900	7.42	1.7494	16.52
Bus WP1101	N/A	1.7466	10.73	1.7508	16.18
Bus WP1103	N/A	1.7452	10.73	1.7494	16.18
Bus EL1101	N/A	1.7452	10.12	1.7494	13.85
Bus EL1102	N/A	1.7452	10.12	1.7494	13.85

Alternative 2 – PG 12 kV buses ECOST

With New OHL from MRT to PG							Without New OHL from MRT to PG					
	Contributing Element		ECOST	Contributing Element		ECOST	Contributing Element		ECOST	Contributing Element		ECOST
No	ID	Type	\$ / yr	ID	Type	\$ / yr	ID	Type	\$ / yr	ID	Type	\$ / yr
1	Bus PG1101		253,110	Bus PG1102		191,188	Bus PG1101		546,381	Bus PG1102		400,433
2	T1_VS	Xfmr2	65,505	T1_VS	Xfmr2	51,363	Line VS_EL	Line	124,966	Line VS_EL	Line	89,736
3	Main Bus+2A+2CT VS	Bus	48,472	Main Bus+2A+2CT VS	Bus	36,959	T1_VS	Xfmr2	65,505	T1_VS	Xfmr2	51,363
4	T1 PG	Xfmr2	36,105	T2 PG	Xfmr2	28,310	Line EL_PG JCT	Line	59,836	Line EL_PG JCT	Line	42,967
5	Bus+4A+2CT 60kV_TrshrVS	Bus	22,547	Bus+4A+2CT 60kV_TrshrVS	Bus	17,192	Main Bus+2A+2CT VS	Bus	48,472	Main Bus+2A+2CT VS	Bus	36,959
6	T2_VS	Xfmr2	21,205	T2_VS	Xfmr2	16,278	T1 PG	Xfmr2	36,105	T2 PG	Xfmr2	28,310
7	Bus VS MAIN	Bus	4,353	Bus VS MAIN	Bus	3,285	Line PG Tap	Line	31,069	Line PG Tap	Line	22,310
8	SW 51	PD	3,789	SW 51	PD	2,807	Bus+4A+2CT 60kV_TrshrVS	Bus	22,547	Bus+4A+2CT 60kV_TrshrVS	Bus	17,192
9	SW 31	PD	3,789	SW 31	PD	2,807	T2_VS	Xfmr2	21,205	T2_VS	Xfmr2	16,278
10	SW 73	PD	3,789	SW 73	PD	2,807	CB32+2CT	PD	20,065	CB32+2CT	PD	15,299
11	SW 21	PD	3,789	SW 21	PD	2,807	Line PG Jct_WP	Line	13,282	Line PG Jct_WP	Line	6,483
12	SW 71	PD	3,789	SW 71	PD	2,807	Bus VS MAIN	Bus	4,353	Bus VS MAIN	Bus	3,285
13	SW 77	PD	3,789	SW 77	PD	2,807	SW 71	PD	3,789	SW 71	PD	2,807
14	SW 41	PD	3,789	SW 41	PD	2,807	SW 73	PD	3,789	SW 73	PD	2,807
15	SW 61	PD	3,789	SW 61	PD	2,807	SW 61	PD	3,789	SW 61	PD	2,807
16	SW 11	PD	3,789	SW 11	PD	2,807	SW 11	PD	3,789	SW 11	PD	2,807
17	CB 422	PD	2,963	LTC PG2	PD	2,115	SW 45_E	PD	3,789	SW 45_E	PD	2,807
18	CB 442	PD	2,963	CB 422	PD	1,446	SW 85_PG	PD	3,789	SW PG2	PD	2,807
19	CB32+2CT	PD	1,785	CB 442	PD	1,446	SW PG1	PD	3,789	SW 85_PG	PD	2,807
20	CB72+2CT	PD	1,785	CB32+2CT	PD	871	SW 75_PG	PD	3,789	SW 75_PG	PD	2,807
21	CB42+2CT	PD	1,785	CB72+2CT	PD	871	SW 31	PD	3,789	SW 31	PD	2,807
22	CB62+2CT	PD	1,785	CB42+2CT	PD	871	SW 33	PD	3,789	SW 33	PD	2,807
23	CB12+2CT	PD	1,785	CB62+2CT	PD	871	SW 41	PD	3,789	SW 41	PD	2,807
24	CB52+2CT	PD	1,472	CB12+2CT	PD	871	SW 51	PD	3,789	SW 51	PD	2,807
25	CB22+2CT	PD	1,472	CB52+2CT	PD	719	SW 77	PD	3,789	SW 77	PD	2,807
26	CCPD 442_O	Bus	423	CB22+2CT	PD	719	SW 21	PD	3,789	SW 21	PD	2,807
27	CCPD 422_O	Bus	423	SWPG42	PD	289	SW 27 WP Tap	PD	3,789	SW 27 WP Tap	PD	2,807
28	CBPG1	PD	417	SWPG22	PD	289	SW 25 PG Tap	PD	3,789	SW 25 PG Tap	PD	2,807
29	CBPG3	PD	417	CCPD 442_O	Bus	207	SW 29	PD	3,789	SW 29	PD	2,807
30	SWPG11	PD	406	CCPD 422_O	Bus	207	SW 47	PD	3,789	SW 47	PD	2,807
31	SWPG31	PD	406	CBPG2	PD	204	SW 49	PD	3,789	SW 49	PD	2,807


Alternative 2 – VS System ECOST

With New OHL from MRT to PG

Without New OHL from MRT to PG


No	Contributing Element		ECOST	No	Contributing Element		ECOST
	ID	Type	\$ / yr		ID	Type	\$ / yr
	System		3,629,745		System		3,929,803
1	T1_VS	Xfmr2	678,972	1	T1_VS	Xfmr2	678,972
2	Main Bus+2A+2CT VS	Bus	496,184	2	Main Bus+2A+2CT VS	Bus	496,184
3	Line MRT_PG	Line	374,065	3	Line VS_EL	Line	406,235
4	Bus+4A+2CT 60kV_TrshrVS	Bus	230,800	4	Bus+4A+2CT 60kV_TrshrVS	Bus	230,800
5	T2_VS	Xfmr2	217,714	5	T2_VS	Xfmr2	217,714
6	T1 MRT	Xfmr2	70,712	6	Line EL_PG JCT	Line	143,847
7	Line EL_PG JCT	Line	66,196	7	CB32+2CT	PD	78,164
8	T1 CL	Xfmr2	51,018	8	T1 MRT	Xfmr2	70,712
9	Line PG Tap	Line	47,619	9	Line PG Tap	Line	61,442
10	Bus VS MAIN	Bus	44,358	10	Line PG Jct_WP	Line	60,652
11	Line PG Jct_WP	Line	40,886	11	T1 CL	Xfmr2	51,018
12	T1 MRM	Xfmr2	39,800	12	Bus VS MAIN	Bus	44,358
13	T1_EL	Xfmr2	39,381	13	T1 MRM	Xfmr2	39,800
14	T1 IN	Xfmr2	38,382	14	T1_EL	Xfmr2	39,381
15	SW 51	PD	38,299	15	T1 IN	Xfmr2	38,382
16	SW 77	PD	38,299	16	SW 71	PD	38,299
17	SW 73	PD	38,299	17	SW 73	PD	38,299
18	SW 71	PD	38,299	18	SW 61	PD	38,299
19	SW 41	PD	38,299	19	SW 11	PD	38,299
20	SW 21	PD	38,299	20	SW 31	PD	38,299
21	SW 11	PD	38,299	21	SW 41	PD	38,299
22	SW 61	PD	38,299	22	SW 51	PD	38,299
23	SW 31	PD	38,299	23	SW 77	PD	38,299
24	T1 PG	Xfmr2	36,105	24	SW 21	PD	38,299
25	CB42+2CT	PD	33,283	25	T1 PG	Xfmr2	36,105
26	CB52+2CT	PD	31,384	26	CB42+2CT	PD	33,283
27	Line IN Tab_IN Sub	Line	29,502	27	CB52+2CT	PD	31,384
28	T2 PG	Xfmr2	28,310	28	Line IN Tab_IN Sub	Line	29,502
29	T1 CC	Xfmr2	27,719	29	T2 PG	Xfmr2	28,310
30	Line VS_PRD Sw's	Line	27,291	30	T1 CC	Xfmr2	27,719

Alternative 3




New 8.8 mile 230 kV OHL from TC Sub to PG Jct. with new PG 230/60 kV Sub
New 2.7 mile 60 kV OHL from PG Jct. to PG Sub

Alternative 3 – New PG Junction 230/60kV Sub



Alternative 3



PG 60 kV Switchyard Rebuilt to a Ring Bus

Alternative 3 – Reliability Results

Bus/Load	Load Sector	W/ New Sub from TC		W/o New Sub from TC	
		Average	Annual	Average	Annual
		Interrupting	Outage	Interrupting	Outage
		Rate	Duration	Rate	Duration
ID		f / yr	hr / yr	f / yr	hr / yr
Bus PG1101	N/A	0.0799	1.16	1.7447	16.43
Bus PG1102	N/A	0.0832	1.24	1.7494	16.52
Bus WP1101	N/A	1.2689	4.61	1.7508	16.18
Bus WP1103	N/A	1.2675	4.61	1.7494	16.18
Bus EL1101	N/A	1.2675	3.99	1.7494	13.85
Bus EL1102	N/A	1.2675	3.99	1.7494	13.85


Alternative 3 – PG 12 kV buses ECOST

With New OHL from MRT to PG							Without New OHL from MRT to PG					
	Contributing Element		ECOST	Contributing		ECOST	Contributing Element		ECOST	Contributing Element		ECOST
No	ID	Type	\$ / yr	ID	Type	\$ / yr	ID	Type	\$ / yr	ID	Type	\$ / yr
1	Bus PG1101		40,763	Bus PG1102		32,880	Bus PG1101		546,381	Bus PG1102		400,433
2	T1 PG	Xfmr2	36,105	T2 PG	Xfmr2	28,310	Line VS_EL	Line	124,966	Line VS_EL	Line	89,736
3	CB 422	PD	2,963	LTC PG2	PD	2,115	T1_VS	Xfmr2	65,505	T1_VS	Xfmr2	51,363
4	CBPG3	PD	417	CB 422	PD	1,446	Line EL_PG JCT	Line	59,836	Line EL_PG JCT	Line	42,967
5	CBPG1	PD	417	SWPG42	PD	289	Main Bus+2A+2CT VS	Bus	48,472	Main Bus+2A+2CT VS	Bus	36,959
6	SWPG11	PD	406	SWPG22	PD	289	T1 PG	Xfmr2	36,105	T2 PG	Xfmr2	28,310
7	SWPG31	PD	406	CBPG4	PD	204	Line PG Tap	Line	31,069	Line PG Tap	Line	22,310
8	CTPG31	Bus	25	CBPG2	PD	204	Bus+4A+2CT 60kV_TrshrVS	Bus	22,547	Bus+4A+2CT 60kV_TrshrVS	Bus	17,192
9	CTPG11	Bus	25	CTPG42	Bus	12	T2_VS	Xfmr2	21,205	T2_VS	Xfmr2	16,278
10			40,763	CTPG22	Bus	12	CB32+2CT	PD	20,065	CB32+2CT	PD	15,299
						32,880	Line PG Jct_WP	Line	13,282	Line PG Jct_WP	Line	6,483
							Bus VS MAIN	Bus	4,353	Bus VS MAIN	Bus	3,285
							SW 71	PD	3,789	SW 71	PD	2,807
							SW 73	PD	3,789	SW 73	PD	2,807
							SW 61	PD	3,789	SW 61	PD	2,807
							SW 11	PD	3,789	SW 11	PD	2,807
							SW 45_E	PD	3,789	SW 45_E	PD	2,807
							SW 85_PG	PD	3,789	SW PG2	PD	2,807
							SW PG1	PD	3,789	SW 85_PG	PD	2,807
							SW 75_PG	PD	3,789	SW 75_PG	PD	2,807
							SW 31	PD	3,789	SW 31	PD	2,807
							SW 33	PD	3,789	SW 33	PD	2,807
							SW 41	PD	3,789	SW 41	PD	2,807
							SW 51	PD	3,789	SW 51	PD	2,807
							SW 77	PD	3,789	SW 77	PD	2,807
							SW 21	PD	3,789	SW 21	PD	2,807
							SW 27 WP Tap	PD	3,789	SW 27 WP Tap	PD	2,807
							SW 25 PG Tap	PD	3,789	SW 25 PG Tap	PD	2,807
							SW 29	PD	3,789	SW 29	PD	2,807
							SW 47	PD	3,789	SW 47	PD	2,807
							SW 49	PD	3,789	SW 49	PD	2,807


Alternative 3 – VS System ECOST

With New Sub from TC				Without New Sub from TC		
No	Contributing Element		ECOST	Contributing Element		ECOST
	ID	Type	\$ / yr	ID	Type	\$ / yr
	System		3,278,223	System		3,929,803
1	T1_VS	Xfmr2	454,863	T1_VS	Xfmr2	678,972
2	Tr NTC 1	Xfmr2	382,044	Main Bus+2A+2CT VS	Bus	496,184
3	Main Bus+2A+2CT VS	Bus	333,054	Line VS_EL	Line	406,235
4	Bus+4A+2CT 60kV_TrshrVS	Bus	154,920	Bus+4A+2CT 60kV_TrshrVS	Bus	230,800
5	T2_VS	Xfmr2	146,068	T2_VS	Xfmr2	217,714
6	Line TC	Line	107,535	Line EL_PG JCT	Line	143,847
7	Line NewSub_PG	Line	100,998	CB32+2CT	PD	78,164
8	T1 MRT	Xfmr2	70,712	T1 MRT	Xfmr2	70,712
9	Line EL_PG JCT	Line	66,196	Line PG Tap	Line	61,442
10	T1 CL	Xfmr2	51,018	Line PG Jct_WP	Line	60,652
11	Line PG Tap	Line	47,619	T1 CL	Xfmr2	51,018
12	Line PG Jct_WP	Line	40,886	Bus VS MAIN	Bus	44,358
13	TC	Syn. Gen	40,644	T1 MRM	Xfmr2	39,800
14	T1 MRM	Xfmr2	39,800	T1_EL	Xfmr2	39,381
15	T1_EL	Xfmr2	39,381	T1 IN	Xfmr2	38,382
16	Line TC_PG	Line	39,298	SW 71	PD	38,299
17	T1 IN	Xfmr2	38,382	SW 73	PD	38,299
18	T1 PG	Xfmr2	36,105	SW 61	PD	38,299
19	Bus VS MAIN	Bus	29,796	SW 11	PD	38,299
20	Line IN Tab_IN Sub	Line	29,502	SW 31	PD	38,299
21	CB42+2CT	PD	28,547	SW 41	PD	38,299
22	T2 PG	Xfmr2	28,310	SW 51	PD	38,299
23	T1 CC	Xfmr2	27,719	SW 77	PD	38,299
24	CB52+2CT	PD	27,479	SW 21	PD	38,299
25	Line VS_PRD Sw's	Line	27,291	T1 PG	Xfmr2	36,105
26	SW 61	PD	25,758	CB42+2CT	PD	33,283
27	SW 11	PD	25,758	CB52+2CT	PD	31,384
28	SW 73	PD	25,758	Line IN Tab_IN Sub	Line	29,502
29	SW 71	PD	25,758	T2 PG	Xfmr2	28,310
30	SW 31	PD	25,758	T1 CC	Xfmr2	27,719

Alternative 4 – Upgraded VS Substation



230kV Upgraded from Collector Bus
to Ring Bus



60kV Upgraded from MTB to BAAH

Alternative 4 – Reliability Results

- Reliability Results for Buses & Loads in PG Sub

Before

After

Bus/Load ID	Load Sector	Average	Annual	Average	Annual
		Interrupting	Outage	Interrupting	Outage
		Rate	Duration	Rate	Duration
		f / yr	hr / yr	f / yr	hr / yr
Bus PG1101	N/A	1.7447	16.43	1.2360	9.86
Bus PG1102	N/A	1.7494	16.52	1.2407	9.95
L1101_Res_PG	Residential	1.7447	16.43	1.2360	9.86
L1101_Com_PG	Commercial	1.7447	16.43	1.2360	9.86
L1101_Ind_PG	Industrial	1.7447	16.43	1.2360	9.86
L1101_Agr_PG	Agricultural	1.7447	16.43	1.2360	9.86
L1102_Res_PG	Residential	1.7494	16.52	1.2407	9.95
L1102_Com_PG	Commercial	1.7494	16.52	1.2407	9.95
L1102_Ind_PG	Industrial	1.7494	16.52	1.2407	9.95
L1102_Agr_PG	Agricultural	1.7494	16.52	1.2407	9.95

Alternative 4 – Reliability Results

Substation	Loads/Feeders	Bank/ Txf #	Original VS Sub		Updated VS Sub	
			Average Interrupting	Annual Outage Duration	Average Interrupting	Annual Outage Duration
			f / yr	hr/yr	f / yr	hr/yr
CC	CC 1101	Bk 1	0.8529	9.24	0.3442	2.76
CL	CL 1101	Bk 1	1.3642	9.28	0.8555	3.10
	CL 1102	Bk 1	1.3642	9.28	0.8555	3.10
	CL 1103	Bk 2	1.3401	9.27	0.8314	3.09
CRL	CRL 1101	Bk 1	0.6625	8.51	0.1538	1.94
	CRL 1102	Bk 2	0.6961	8.86	0.1874	2.29
	CRL 1103	Bk 1	0.6625	8.51	0.1538	1.94
EL	EL 1101	Bk 1	1.7494	13.85	1.2407	7.28
	EL 1102	Bk 1	1.7494	13.85	1.2407	7.28
IN	IN 1101	Bk 2	1.3401	9.80	0.8314	3.62
LND	LND 1101	Bk 1	0.1678	2.15	0.1678	2.15
	LND 1102	Bk 1	0.1678	2.15	0.1678	2.15
	LND 1103	Bk 1	0.1678	2.15	0.1678	2.15
	LND 1104	Bk 1	0.1678	2.15	0.1678	2.15
MRT	MRT 1101	Bk 1	0.6857	8.36	0.1306	2.09
	MRT 1102	Bk 1	0.6857	8.36	0.1306	2.09
	MRT 1103	Bk 1	0.6857	8.36	0.1306	2.09
MRM	MRM 1101	Bk 1	0.1349	1.67	0.1349	1.67
	MRM 1102	Bk 1	0.1349	1.67	0.1349	1.67
NB	NB 1101	Bk 1	0.8461	8.92	0.3374	2.45
OL	OL 1101	Bk 1	0.0528	1.41	0.0528	1.41
	OL 1102	Bk 2	0.0817	1.48	0.0817	1.48
PG	PG 1101	Bk 1	1.7447	16.43	1.2360	9.86
	PG 1102	Bk 2	1.7494	16.52	1.2407	9.95
WP	WP 1101	Bk 2	1.7508	16.18	1.2421	9.62
	WP 1102	Bk 3	1.7494	16.18	1.2407	9.61

Alternative 4 – PG 12 kV buses ECOST

Original VS System						VS System with New VS Sub					
Contributing Element		ECOST	Contributing Element		ECOST	Contributing Element		ECOST	Contributing Element		ECOST
ID	Type	\$ / yr	ID	Type	\$ / yr	ID	Type	\$ / yr	ID	Type	\$ / yr
Bus PG1101		546,381	Bus PG1102		400,433	Bus PG1101		320,639	Bus PG1102		231,619
Line VS_EL	Line	124,966	Line VS_EL	Line	89,736	Line VS_EL	Line	124,966	Line VS_EL	Line	89,736
T1_VS	Xfmr2	65,505	T1_VS	Xfmr2	51,363	Line EL_PG JCT	Line	59,836	Line EL_PG JCT	Line	42,967
Line EL_PG JCT	Line	59,836	Line EL_PG JCT	Line	42,967	T1 PG	Xfmr2	36,105	T2 PG	Xfmr2	28,310
Main Bus+2A+2CT VS	Bus	48,472	Main Bus+2A+2CT VS	Bus	36,959	Line PG Tap	Line	31,069	Line PG Tap	Line	22,310
T1 PG	Xfmr2	36,105	T2 PG	Xfmr2	28,310	Line PG Jct_WP	Line	13,282	Line PG Jct_WP	Line	6,483
Line PG Tap	Line	31,069	Line PG Tap	Line	22,310	SW91	PD	5,170	SW91	PD	3,901
Bus+4A+2CT 60kV_TrshrVS	Bus	22,547	Bus+4A+2CT 60kV_TrshrVS	Bus	17,192	SW90	PD	5,170	SW90	PD	3,901
T2_VS	Xfmr2	21,205	T2_VS	Xfmr2	16,278	SW 45_E	PD	3,789	SW 45_E	PD	2,807
CB32+2CT	PD	20,065	CB32+2CT	PD	15,299	SW 85_PG	PD	3,789	SW PG2	PD	2,807
Line PG Jct_WP	Line	13,282	Line PG Jct_WP	Line	6,483	SW PG1	PD	3,789	SW 85_PG	PD	2,807
Bus VS MAIN	Bus	4,353	Bus VS MAIN	Bus	3,285	SW 75_PG	PD	3,789	SW 75_PG	PD	2,807
SW 71	PD	3,789	SW 71	PD	2,807	SW 27 WP Tap	PD	3,789	SW 27 WP Tap	PD	2,807
SW 73	PD	3,789	SW 73	PD	2,807	SW 25 PG Tap	PD	3,789	SW 25 PG Tap	PD	2,807
SW 61	PD	3,789	SW 61	PD	2,807	SW 29	PD	3,789	SW 29	PD	2,807
SW 11	PD	3,789	SW 11	PD	2,807	SW 47	PD	3,789	SW 47	PD	2,807
SW 45_E	PD	3,789	SW 45_E	PD	2,807	SW 49	PD	3,789	SW 49	PD	2,807
SW 85_PG	PD	3,789	SW PG2	PD	2,807	SW 27	PD	3,789	SW 27	PD	2,807
SW PG1	PD	3,789	SW 85_PG	PD	2,807	CB7-1	PD	1,300	LTC PG2	PD	2,115
SW 75_PG	PD	3,789	SW 75_PG	PD	2,807	CB6-1	PD	1,300	SACT_PG2	Bus	803
SW 31	PD	3,789	SW 31	PD	2,807	CB 12_WP	PD	1,300	CB7-1	PD	635
SW 33	PD	3,789	SW 33	PD	2,807	SA_PG1	Bus	959	CB6-1	PD	635
SW 41	PD	3,789	SW 41	PD	2,807	SW 13_1_WP	PD	583	CB 12_WP	PD	635
SW 51	PD	3,789	SW 51	PD	2,807	SW 95_WP	PD	583	SW 13_1_WP	PD	284
SW 77	PD	3,789	SW 77	PD	2,807	SW 17	PD	583	SW 95_WP	PD	284
SW 21	PD	3,789	SW 21	PD	2,807	Fuse 1_E	PD	86	SW 17	PD	284
SW 27 WP Tap	PD	3,789	SW 27 WP Tap	PD	2,807	Fuse WP	PD	86	Fuse 1_E	PD	42
SW 25 PG Tap	PD	3,789	SW 25 PG Tap	PD	2,807	Fuse PG1	PD	86	Fuse WP	PD	42
SW 29	PD	3,789	SW 29	PD	2,807	CT 12_1_WP	Bus	86	Fuse PG1	PD	42
SW 47	PD	3,789	SW 47	PD	2,807	Bus177	Bus	86	CT 12_1_WP	Bus	42
SW 49	PD	3,789	SW 49	PD	2,807	Bus175	Bus	86	Bus177	Bus	42

Alternative 4 – VS System ECOST

Original VS Sub				New VS Sub		
No	Contributing Element	Type	ECOST	Contributing Element	Type	ECOST
	ID		\$ / yr	ID		\$ / yr
	System		3,929,803	System		1,700,614
1	T1_VS	Xfmr2	678,972	Line VS_EL	Line	406,235
2	Main Bus+2A+2CT VS	Bus	496,184	Line EL_PG JCT	Line	143,847
3	Line VS_EL	Line	406,235	T1 MRT	Xfmr2	70,712
4	Bus+4A+2CT 60kV_TrnsfrVS	Bus	230,800	Line PG Tap	Line	61,442
5	T2_VS	Xfmr2	217,714	Line PG Jct_WP	Line	60,652
6	Line EL_PG JCT	Line	143,847	T1 CL	Xfmr2	51,018
7	CB32+2CT	PD	78,164	T1 MRM	Xfmr2	39,800
8	T1 MRT	Xfmr2	70,712	T1_EL	Xfmr2	39,381
9	Line PG Tap	Line	61,442	T1 IN	Xfmr2	38,382
10	Line PG Jct_WP	Line	60,652	T1 PG	Xfmr2	36,105
11	T1 CL	Xfmr2	51,018	Line IN Tab_IN Sub	Line	29,502
12	Bus VS MAIN	Bus	44,358	T2 PG	Xfmr2	28,310
13	T1 MRM	Xfmr2	39,800	T1 CC	Xfmr2	27,719
14	T1_EL	Xfmr2	39,381	Line VS_PRD Sw's	Line	27,291
15	T1 IN	Xfmr2	38,382	Bus MRT 60kV	Bus	24,996
16	SW 71	PD	38,299	T1 LN	Xfmr2	24,084
17	SW 73	PD	38,299	T1_CRL	Xfmr2	23,162
18	SW 61	PD	38,299	TSpares MRT	Xfmr2	22,713
19	SW 11	PD	38,299	Line IN Tap_MRT lJct	Line	22,337
20	SW 31	PD	38,299	SW91	PD	17,293
21	SW 41	PD	38,299	SW90	PD	17,293
22	SW 51	PD	38,299	T1 NB	Xfmr2	16,924
23	SW 77	PD	38,299	T1 OL	Xfmr2	14,077
24	SW 21	PD	38,299	T2 CL	Xfmr2	13,104
25	T1 PG	Xfmr2	36,105	SW 45_E	PD	12,541
26	CB42+2CT	PD	33,283	SW 47	PD	12,541
27	CB52+2CT	PD	31,384	SW 49	PD	12,541
28	Line IN Tab_IN Sub	Line	29,502	SW 27	PD	12,541
29	T2 PG	Xfmr2	28,310	Line PRD Sw's_CP Tap	Line	12,490
30	T1 CC	Xfmr2	27,719	Line CP Tap_CL Sub	Line	12,009

Task Five – Final Results

		VS System Improvements (%)				PG Improvements (%)	
Alternative	Description	SAIFI	SAIDI	EENS	ECOST	EENS	ECOST
1	Installation of a New 60kV OHL between VS & PG Substation	3%	2%	2%	2%	55%	53%
2	Installation of a New 60 kV OHL from MRT Sub to PG Substation	11%	9%	8%	8%	55%	53%
3	Installation of a New 230 kV OHL from TC Sub to PG Jct., Combined with the Erection of a New 230/60 kV Substation at PG Junction	0%	19%	17%	17%	93%	92%
4	Upgraded VS Substation	41%	53%	54%	57%	40%	42%

Project Conclusion

- Commercially Available Software, ETAP, was Utilized
- The VS System was Selected, Modeled and Benchmarked
- The Model Successfully Predicted Reliability Improvements due to Various Investment Alternatives

Impact of Project on Total Cost of Ownership (TCO)

- Key Systems Can be Modeled and Benchmarked
- Major Contributors to Poor Reliability Can be Identified
- Prospective Reliability Upgrade Projects Can be Identified
- Estimated Project Costs Can be Determined
- All Projects Can be Prioritized on Cost Benefit Scale

Systematic Prioritization of Reliability Improvement Projects
Ensures that Available Budgets are Deployed More Effectively

Next Steps

- Quantify PUC, Shareholder and/or Customer Goals and Schedules
- Capture Impacts of Upgrades on Remainder of 230kV System
- Capture Other Reliability Related Costs (e.g., Maintenance)
- Capture Reliability Option Upgrade Costs
- Perform Final Cost Benefit Calculations
- Model Other High-Impact Systems and Make System Wide Investment Priority Decisions
- Implement and Expand Reliability Related Component and System Data Capture

Questions?

Reminders

Automation & Power World 2011

- Please be sure to complete the workshop evaluation
- Professional Development Hours (PDHs) and Continuing Education Credits (CEUs):
 - You will receive a link via e-mail to print certificates for all the workshops you have attended during Automation & Power World 2011.
 - **BE SURE YOU HAVE YOUR BADGE SCANNED** for each workshop you attend. If you do not have your badge scanned you will not be able to obtain PDHs or CEUs.

**Power and productivity
for a better world™**

