

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the factory

VIDEOTON - Bulgarian Holdings EOOD  
Nikola Petkov No. 10, 6000 STARA ZAGORA  
BULGARIA*Note: When more than one factory, please report on page 2* Additional Information on page 2

Ratings and principal characteristics

Ie = 16 / 25 / 32 / 40 / 45 / 50 / 63 / 80 / 100 / 125 A  
AC-22A: 240 V a.c.; 1-pole; AC-22A: 415 V a.c.; 2-, 3- and 4-  
pole; DC-21B: 60 V d.c.; 1 and 2-pole

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series E 200

Additional information (if necessary may also be reported on page 2)

Siehe Prüfbericht / see test report

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007; 60947-1:2007/AMD1:2010  
IEC 60947-1:2007/AMD2:2014  
IEC 60947-3:2008; 60947-3:2008/AMD1:2012  
IEC 60947-3:2008/AMD2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

257614-TL3-1

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierung Produkte / Certification Products



Date: 2019-02-15

Signature:

J. Richter