



Test Report				Date of issue: 4.6.2014						
				Serial No.: 3GF11094423						
				Type: M3JP 200MLA 8 IMB3/IM1001						
				Product Code: 3GJP204410-ADG						
				Protection type: Ex d IIB T4 Gb						
				Cert. No.: LCIE 10 ATEX 3061X / IECEX LCI 04.0011X						
Rating:										
		V	Hz	kW	r/min	A	cos φ	Duty		
3-Motor		400	D	50	15	734	30,4	0,79	S1	
Insul.cl.F		415	D	50	15	735	30,1	0,77	S1	
IP55		690	Y	50	15	734	17,7	0,79	S1	
400 V 50Hz : 89.9(100%) - 90.3(75%) - 89.6(50%)										
Resistance Line				Ambient: 11,5 °C			Insulation resistance at 42,0 °C		Overload	
U ₁ - V ₁				0,47350 Ω			5000 MΩ		1000 V	
U ₁ - W ₁				0,47360 Ω					Torque 160 % 15s	
V ₁ - W ₁				0,47360 Ω						
				High-voltage test winding			2900 V		1 s	
Test	Torque [Nm]	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	n[r/min]	cos φ	η [%]	
No load test		400,5 D	50	14,6	0,67		750	0,07		
Locked rotor test		88,5 D	50	30,4	1,86		0	0,40		
Thermal test (100% load)	195,2	400,0 D	50	30,6	16,8	15,0	734	0,79	89,2	
Partial load points:										
~75% load	146,4	400,2 D	50	24,6	12,5	11,3	739	0,74	89,7	
~50% load	97,2	400,1 D	50	19,6	8,45	7,50	743	0,62	88,8	
~25% load	48,2	400,2 D	50	15,8	4,50	3,75	747	0,41	83,4	
Temperature rise at rated load.				[°C]	[K]	Method		Measurement method		
Stator winding :				71,1	1	1		Resistance		
Frame :				49,1	2	2		Thermometer		
Bearing D-end :				53,9	2	2		Thermocouples		
Ambient Temperature :				25,0	2					
Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss.										
On behalf of customer										
On behalf of manufacturer			Date of test			3.2.2012				
Tested by ABB Oy, Motors and Generators, Vaasa, Finland						Telephone +358 10 2211 Telefax +358 10 22 47372				

Computer print-out valid without signature.