

**IEC****IECEE**

®

™

Ref. Certif. No.

CN54731

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Fuse switch disconnecter

Name and address of the applicant

ABB Oy  
Muottitie 2A FI-65320 VAASA, Finland

Name and address of the manufacturer

ABB Oy  
Muottitie 2A FI-65320 VAASA, Finland

Name and address of the factory

ABB Bulgaria EOOD – Rakovski branch  
BULGARIA, 4142 Village of Stryama, Region of Plovdiv,  
Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial  
Road 1, nr.14-18

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp: 8kV; Ui: 1000V; Ith: 160A(AC400V, AC500V), 125A(AC690V, AC1000V);  
AC-21B: Ue/Ie: 690V/125A; AC-22B: Ue/Ie: 500V/160A;  
AC-23B: Ue/Ie: 400V/160A; AC-22B: Ue/Ie: 1000V/125A; Iq: 100 kA(400Vac, 500Vac, 690Vac),  
120 kA(1000Vac); 50/60Hz; IP30(front); 3P

Trademark / Brand (if any)

ABB

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

ZLBM00, ZHBM00;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020; IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-098875

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: Sep.15,2021

Signature:

谢肇旭

Xie ZhaoXu

**CB 0064356**