

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Surge protective devices

Name and address of the applicant

ABB STOTZ-KONTAKT GmbH  
Eppelheimer Str. 82  
69123 Heidelberg  
Germany

Name and address of the manufacturer

DEHN SE  
Hans-Dehn-Str. 1  
92318 Neumarkt  
Germany

Name and address of the factory

*Note: When more than one factory, please report on page 2*DEHN SE  
Hans-Dehn-Str. 1  
92318 Neumarkt  
Germany Additional information on page 2

Ratings and principal characteristics

Un = 230 / 400 V~, Uc = 264 V~  
Up = 1,5 kV, In = 25 kA, Iimp = 25 kA  
IL= 125 A

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

OVR T1-T2 1L 25-255 P  
OVR T1-T2 1L 25-255 P TS

Additional information (if necessary may also be reported on page 2)

 Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

2268291.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
Arnhem, 6825 MJ  
Netherlands

Date: 2022-09-12

Signature: H.L. Schendstok