

Emax-Air Circuit Breakers



E3 3200A Fixed and Drawout

AC Circuit Breakers and Switches

Fixed and Drawout

3 and 4 Pole

Field Interchangeable Modular Trip Units

Extremely Simple Installation

Standardized Accessories Across the Entire Range

Higher Performances in Less Space

Multiple Communication Options

E3X-A Fuseless 200kA Technology



Dimensions

	3P Fixed	16.46H x 15.91W x 11.89D
	3P Drawout	18.15H x 17.01W x 15.61D
E3X-A	3P Fixed	17.42H x 15.91W x 11.89D
	3P Drawout	18.94H x 17.01W x 15.61D

Compliance with Global Standards

UL 1066

ANSI C37, C37.13, C37.16, C37.17, C37.50

Also available as:

IEC 60947, EN 60947, CEI EN 60947, IEC 6100

CCC

Marine and others

The ABB Quality System complies with the international ISO 9001 - 2000 Standard (model for quality assurance in design, development, construction, and installation and service) and with the equivalent European EN ISO 9001 and Italian UNI EN ISO 9001 Standards

UL 1066

E3

		N-A	S-A	H-A	V-A	X-A
Levels of performance						
Frame Size	[A]	2000	800	800	800	800
	[A]	2500	1200	1200	1200	1200
	[A]		1600	1600	1600	1600
	[A]		2000	2000	2000	2000
	[A]		2500	2500	2500	
	[A]		3200	3200	3200	
Capacity of neutral pole for four-pole circuit breakers	[%Iu]	100	100	100	100	100
Rated short circuit current						
240V	[kA]	65	85	85	125	200
480V	[kA]	50	65	85	125	200
600V	[kA]	50	65	85	100	14
Rated short time current	[kA]	50	65	65	85	14



Connections

Rear connections-Horizontal (standard on fixed breaker) or Vertical

Trip Unit

The latest generation electronics from ABB have made it possible to design the new, revolutionary PR121, PR122 and

PR123 trip units. The re-engineered hardware architecture allows flexible and precise configuration. With the new Emax modular trip units one can simply add the appropriate module to satisfy your requirement: a great advantage, both in terms of flexibility and customization.

Weight (lbs)	3P Fixed	145
	3P Drawout	229

Auxiliary Devices for Indication and Control

Control

- Shunt trip/closing coil (YO/YC) and second shunt trip (YO2)
- Undervoltage release (YU)
- Time-delay device for undervoltage release (D) IEC only
- External current sensors for neutral conductor outside circuit breaker (neutral CTS)
- Homopolar toroid for the main power supply grounding conductor (star center of the transformer)
- Mechanical operation counter

Indication

- Gear motor for the automatic charging of the closing springs (M)
- Bell alarm
- Bell alarm with remote reset command
- Electrical signaling of circuit breaker open/closed (Aux contacts - MOC)
- Electrical signaling of circuit breaker racked-in/test isolated/racked-out (position contacts -TOC)
- Contact signaling closing springs charged
- Contact signaling undervoltage release de-energized (C. Aux YU)

Safety

- Lock in open position: key
- Lock in open position: padlocks
- Circuit breaker lock in racked-in/test isolated/racked-out position
- Accessories for lock in test isolated/racked-out position
- Padlock device for safety shutter
- Mechanical lock for compartment door
- Anti-racking-out device when the springs are charged (FAIL SAFE)
- Protection for opening and closing pushbuttons
- Mechanical interlock



ABB Inc.

1206 Hatton Road
Wichita Falls, TX 76302
For more information and
the location of your local
field office please go to
www.abb-control.com