



Test Report				Date of issue: 4.6.2014					
				Serial No.: 0751-010227548					
				Type: M3KP 160MLB 6 B3					
				Product Code: 3GKP163420-H					
				Protection type: Ex de IIB T4 Gb					
				Cert. No.: LCIE 11 ATEX 3087X / IECEx LCI 09.0008X					
Rating:									
	V	Hz	kW	r/min	A	cos φ	Duty		
3~Motor	400	D 50	11	972	21,7	0,81	S1		
Insul.cl.F	415	D 50	11	975	21,4	0,79	S1		
IP55	690	Y 50	11	972	12,6	0,81	S1		
Eff class IE2 400 V 50Hz : IE2 - 90.1(100%) - 90.8(75%) - 90.4(50%)									
Resistance				Insulation resistance at 22,0 °C		Overload			
Line	Ambient: 22,0 °C			20000 MΩ 1000 V		Torque 160% 15s			
U ₁ - V ₁	0,58500 Ω								
U ₁ - W ₁	0,58520 Ω								
V ₁ - W ₁	0,58600 Ω								
				High-voltage test winding 2400 V		60 s			
Test	Torque [Nm]	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	n[r/min]	cos φ	η [%]
No load test		400,1 D	50	10,3	0,39		1000	0,06	
Locked rotor test		93,6 D	50	23,1	1,31		0	0,35	
Thermal test (100% load)	138,7	400,0 D	50	22,1	12,2	11,0	973	0,80	90,1
Partial load points:									
~75% load	80,2	400,0 D	50	17,8	9,10	8,24	981	0,74	90,6
~50% load	53,9	400,0 D	50	14,2	6,20	5,58	988	0,63	90,0
~25% load	26,8	400,0 D	50	11,4	3,26	2,79	995	0,41	85,7
Temperature rise at rated load.				[°C]	[K]	Method		Measurement method	
Stator winding :				50,2	30,0	1		1 Resistance	
Frame :				30,0	29,0	2		2 Thermometer	
Bearing D-end :				29,0	78,5	2		3 Thermocouples	
Rotor:				78,5	25,0	3			
Ambient Temperature :				25,0		2			
Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss.									
On behalf of customer									
On behalf of manufacturer			Date of test		9.7.2008				
Tested by ABB Oy, Motors and Generators, Vaasa, Finland						Telephone +358 10 2211 Telefax +358 10 22 47372			

Computer print-out valid without signature.