



Product Service

# CERTIFICATE

No. B 044254 0021 Rev. 00

**Holder of Certificate:** **ABB Stotz-Kontakt GmbH**

Eppelheimer Str. 82  
69123 Heidelberg  
GERMANY

**Certification Mark:**



**Product:**

**Power supplies**  
**( AC-DC Din Rail Mountable Power Supplies )**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 6121020053601

**Valid until:** 2024-06-17

**Date,** 2020-09-23

( Owen Hsu )

# CERTIFICATE

No. B 044254 0021 Rev. 00

**Model(s):** CP-D 24/2.5

**Brand Name:** ABB



**Parameters:**

|                           |           |
|---------------------------|-----------|
| Rated inputs:             | See below |
| Rated outputs:            | See below |
| Protection class:         | II        |
| Max. ambient temperature: | 55 °C     |

**Remarks:**

1. When installing, all requirements of below mentioned test standards must be fulfilled.
2. The equipment is evaluated for operating in altitude up to 5,000 m above the sea level.

**The ratings & model description of the models are as below:**

| Model-#     | Input rating                      | Output Voltage | Output Current | Output Power |
|-------------|-----------------------------------|----------------|----------------|--------------|
| CP-D 24/2.5 | 100-240 Vac,<br>47-63 Hz, 1500 mA | 24 Vdc         | 2.5 A          | 60 W         |

**Tested according to:** EN 62368-1:2014

**Production Facility(ies):** 004727, 004978