

# CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC  
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



## STATEMENT OF TEST RESULTS

STR/2596/IMQ

Product	<b>Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)</b>
Tested by request of	<b>ABB S.p.A. Via Vittor Pisani 16 20124 Milano (MI)</b>
Manufactured at (name and place)	<b>ABB S.p.A. Via Ardeatina 2491 00040 Santa Palomba (RM)</b>
Preliminary visit carried out by	—
Rating and principal characteristics	<b>1P+N – Un = 230 V – Curve B or C In = 6, 10, 13, 16, 20, 25, 32 or 40 A Type A or APR – I<sub>Δn</sub> = 30 mA; I<sub>cn</sub> = 6000 A; I<sub>Δm</sub> = 6000 A (see also pages 4, 6 and 7 of Test Report PB18-0033295-01-00)</b>
Trade mark (if any)	<b>ABB</b>
Model/Type Ref.	<b>Series DS201 T (see pages 6 and 7 of Test Report PB18-0033295-01-00)</b>
Additional information (if necessary)	<b>Testing location/procedure: CTF Stage 2</b>
A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)	
<ul style="list-style-type: none"><li>• EN 61009-1:2012 + A1:2014 + A2:2014 + A11:2015 + A12:2016</li><li>• EN 61009-2-1:1994 + A11:1998</li></ul>	
as shown in the test reports (reference No.)	<b>PB18-0033295-01-00 and from PB18-0033295-01-00 to PB18-0033295-01-17</b>

This Statement of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the above mentioned standard.

This Statement of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA may recognize this Statement as a basis for granting a national mark of conformity or a national approval, as specified in OD 6, List of current decisions of CCA Group, point 2.11.

**IMQ S.p.A.**

Milano, 2019-01-11

Signature of the authorized person \_\_\_\_\_

Name and function of the authorized person

**Mauro Casari**  
**B.U. "Product Conformity Assessment"**  
**"Project Management & Certification" Area**  
**"Certification" Sector (voluntary field) - Manager**

Tel.: (+39) 02-50731  
Fax.: (+39) 02-50991500  
e-mail: info@imq.it