

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Circuit breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the factory

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY*Note: When more than one factory, please report on page 2* Additional Information on page 2

Ratings and principal characteristics

Un = 230/400 V a.c.; In = 0,5 ... 63 A; Characteristic C

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series SR200T

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007
IEC 60947-1:2007/AMD1:2010
IEC 60947-1:2007/AMD2:2014
IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

259368-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2019-06-13

Signature:


R. Nickel



Ref. Certif. No.

DE1-62141

ABB Bulgaria EOOD - Rakovski Branch -
Rakovski Industrial zone, 14, Industrial Road 1, 4142
RAKOVSKI
BULGARIA

Additional information (if necessary)

Requirements according to national standard VC 8036:2015; Government Notice 1023 of 2015 (Government Gazette No. 39324); SANS 556-1:2018 (power factor 0,5; recovery voltage 252/436 V a.c.) were tested.

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2019-06-13

Signature:



R. Nickel