



NOTIFICATION OF TEST RESULTS

CCA/DE1 34887

Product	Leitungsschutzschalter / Circuit-breaker
Tested by request of	ABB-Stotz-Kontakt GmbH Eppelheimer Straße 82, 69123 Heidelberg, GERMANY
Manufactured at (name and place)	ABB LV Installation Materials Co. Ltd., Beijing Materials Co. Ltd., Beijing, No.17, Kangding Street,, Beijing Economic-Tech. Developm. Area, 100176 Beijing, Beijing CHINA
Preliminary visit carried out by	
Rating and principal characteristics	AC 230V; AC 230/400V; AC 400V; B 1-63A; C/D 0,5-63A Nmer of poles: 1; 2; 3; 4; 1+N, 3+N Instantaneous tripping current B; C; D; Icn: S 20. (6kA); S 20.L (4,5kA)
Trade mark (if any)	
Model/Type Ref.	Serie / series S 20. ; S 20. L
Additional information (if necessary)	CTF Stage 2
A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)	
EN 60898-1:2019	
as shown in the test reports (reference No.) 298641-TL3-4	

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body which participates directly in the CENELEC Certification Agreement (CCA) of September 11th, 1973 as revised on March 29th, 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA.

<p>The CCA Testing Laboratories are accredited by DAkkS according to DIN EN ISO/IEC 17025:2018.</p> <p>The accreditation is valid only for the scope listed in the Annex to the accreditation certificates D-PL-12107-01-00 (IPH) and D-PL-12061-01-01 (VDE Institute) as well as in the published list for flexible accreditation available at the VDE website.</p>	<p>VDE Prüf- und Zertifizierungsinstitut GmbH</p> <p>Stamp and signature of the authorized person J. Richter Name, Certification Officer</p>
<p>Offenbach, 2022-08-02</p>	

<p>VDE Prüf- und Zertifizierungsinstitut GmbH Merianstrasse 28, 63069 Offenbach, Germany</p>	<p>Tel.: +49 69 8306-0 Fax.: +49 69 8306-555 Email: vde-institut@vde.com</p>
--	--