



产品认证证书

证书编号: CQC2013010304604041

申请人名称及地址

ABB France
2 rue d'Arsonval 69680 Chassieu France

制造商名称及地址

ABB France
2 rue d'Arsonval 69680 Chassieu France

生产企业名称及地址

Linaset a. s. (V054073)
Geskoslovenske armady 362, Budisov 74787 nad Budisovkou Czech Republic

产品名称和系列、规格、型号

辅助触头

CA5-**, CAL5-**: Ui:690V;Uimp:6kV;AC-15:Ue/Ie:AC24-127V/6A, AC220-240V/4A, AC380-440V/3A, AC500-690V/2A; DC-13:Ue/Ie:DC24V/6A, DC48V/2.8A, DC72V/1A, DC110-125V/0.55A, DC220-250V/0.3A; Ith:16A; IP20; 型号解释见附件

产品标准和技术要求

GB/T 14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020年08月21日 有效期至: 2022年12月19日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任: _____

陆楠



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0355311



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2013010304604041

NAME AND ADDRESS OF THE APPLICANT

ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE FACTORY

Linaset a.s. (V054073)
Ceskoslovenske armady 362, Budisov 74787 nad Budisovkou Czech Republic

PRODUCT NAME, MODEL AND SPECIFICATION

Auxiliary contacts

CA5-**,CAL5-**: Ui:690V;Uimp:6kV;AC-15:Ue/Ie:AC24-127V/6A,AC220-240V/4A,AC380-440V/3A,AC500-690V/2A;DC-13:Ue/Ie:DC24V/6A,DC48V/2.8A,DC72V/1A,DC110-125V/0.55A,DC220-250V/0.3A;Ith:16A;IP20;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.21,2020

Valid until: Dec.19,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0355311



产品认证证书

第 1 页 共 1 页

附 录

证书编号: CQC2013010304604041

纸 号: 355311

型号解释:

NOMENCLATURE:

CA5/CAL5 —10
I II

I—Main designation 系列代号:

CA5 Auxiliary contact module, front mounted 辅助触头, 前装

CAL5 Auxiliary contact module, lateral mounted 辅助触头, 侧装

II—Auxiliary Pole Construction 辅助触点配置

01—0 Normally Opened and 1 Normally Closed. 1 常闭

10—1 Normally Opened and 0 Normally Closed. 1 常开

11—1 Normally Opened and 1 Normally Closed. 1 常开, 1 常闭

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>