



Test Report				Date of issue: 28.8.2013						
Customer: ABB OY				Serial No.:						
Customer ref.: 4207932				Tag No.: 3GF11094419						
				Order No.: 599608-4						
				Type: M3GP 180MLB 2 IMB3/IM1001						
				Product Code: 3GGP181420-ADD						
				Protection type: Ex nA II C T3 Gc						
				Cert. No.: LCIE 13 ATEX 1034 X						
				IECEx LCIE 13.0047X						
Rating:										
		V	Hz	kW	r/min	A	cos φ	Duty		
3-Motor		690	Y	50	30	2943	30,2	0,90	S1	
Insul.cl.F		400	D	50	30	2943	52	0,90	S1	
IP55		415	D	50	30	2948	50	0,90	S1	
Eff class IE2		50Hz : IE2 - 92.5(100%) - 93.0(75%) - 92,6(50%)								
Resistance				Insulation resistance at 28,0 °C			Overload			
Line		Ambient: 19,5 °C		18000 MΩ 1000 V			Torque 160 % 15s			
U <sub>1</sub> - V <sub>1</sub>		0,14380 Ω								
U <sub>1</sub> - W <sub>1</sub>		0,14350 Ω								
V <sub>1</sub> - W <sub>1</sub>		0,14340 Ω								
				High-voltage test winding 2900 V			1 s			
Test	Torque [Nm]	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	n[r/min]	cos φ	η [%]	
No load test		399,9	D 50	13,4	0,89			0,10		
Locked rotor test		67,4	D 50	52,0	2,49			0,41		
Thermal test (100% load)		400,1	D 50	52,2	32,5	30,0	2948	0,90	92,2	
Partial load points:										
~75% load		399,8	D 50	39,8	24,2	22,5	2969	0,88	92,9	
~50% load		400,1	D 50	28,4	16,3	15,0	2983	0,83	92,3	
~25% load		400,1	D 50	18,6	8,48	7,50	2994	0,66	88,4	
Temperature rise at rated load.				°C	K	Method		Measurement method		
Stator winding :				57,4	1			1 Resistance		
Frame :				20,5	2			2 Thermometer		
Bearing D-end :				28,3	2			3 Thermocouples		
Rotor :				74,2	3					
Ambient Temperature :		25,0			2					
Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1.										
PLL determined from residual loss.										
On behalf of customer										
On behalf of manufacturer			Date of test		17.1.2012					
Tested by ABB Oy, Motors and Generators, Vaasa, Finland							Telephone		+358 10 2211	
							Telefax		+358 10 22 47372	

Computer print-out valid without signature.