产品认证证书

II型自愿认证

证书编号：CQC2011010309464423

发证日期：2022年02月15日
有效期至：2030年12月04日

委托人名称及注册地址	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
制造商名称及注册地址	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
生产企业名称及生产地址	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
产品名称和系列、规格、型号	热过载继电器 TF42, TF42B;详见附件
产品标准和技术要求	GB/T 14048.4-2020
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC12-000001-2020认证规则的要求，特发此证。

本证书为变更证书，证书首次颁发日期：2020年09月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站（www.cnca.gov.cn）查验证书信息

授权签字人 陈昕　　签发 谢肇煦

中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心

C(2) 0138147

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2011010309464423

Valid from: Feb.15,2022

Valid until: Dec.04,2030

NAME AND REGISTERED ADDRESS OF THE APPLICANT	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
NAME AND LOCATION OF THE FACTORY	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
PRODUCT NAME, MODEL AND SPECIFICATION	Thermal Overload Relay TF42, TF42B;See the appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.4-2020
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.02,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn

SIGN BY 陈昕

SIGNATURE 谢肇煦

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心

http://www.cqc.com.cn Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China Tel: +86 10 83886666

C(2) 0138147

产品认证证书

II型自愿认证

证书编号：CQC2011010309464423

本证书及附件应同时使用，信息查验说明见证书页

纸号：138147

TF42, TF42B

Ui: 690V;

Uimp: 6kV;

Ue: 690V;

Ie:0.1-0.13A,0.13-0.17A,0.17-0.23A,0.23-0.31A,0.31-0.41A,0.41-0.55A,0.55-0.74A,0.74-1A,1-1.3A,1.3-1.7A,1.7-2.3A,2.3-3.1A,3.1-4.2A,4.2-5.7A,5.7-7.6A,7.6-10A,10-13A,13-16A,16-20A,20-24A,24-29A,29-35A,35-40A;

脱扣级别: 10;

极数: 3P;

外壳防护等级:IP20;

配用的辅助触头:(本体)

1NO1NC;

Ith: 4A（NO）, 6A（NC）;

NC(95/96):

AC-15: Ue/Ie: 120V/240V/3A,380V/0.95A,500V/0.75A,600V/0.6A;

DC-13: Ue/Ie: 24V/1.25A,60V/125V/0.55A,250V/0.27A,500V/0.15A,600V/0.1A;

NO(97/98):

AC-15: Ue/Ie: 120V/240V/380V/500V/0.5A;

DC-13: Ue/Ie: 24V/1.25A,60V/125V/0.55A,250V/0.27A,500V/0.15A,600V/0.1A;

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心

CQC 中国质量认证中心

产品认证证书

II型自愿认证

证书编号：CQC2011010309464423

本证书及附件应同时使用，信息查验说明见证书页

纸号：138147

型号解释：

T	F	42	-	0.13	B
1	2	3		4	5

1. Thermal Overload Relay 热过载继电器
2. F is for the use with the AF- contactor series 用于 AF 系列接触器
3. Frame current 框架等级
4. Rated current 额定电流
5. blank: standard version 空白：标准规格
   B: Railway Application; B：轨道专用

中国质量认证中心

产品认证证书

II型自愿认证

证书编号：CQC2011010309464423

本证书及附件应同时使用，信息查验说明见证书页

纸号：138147

Order code 产品代号	type 型号	Order code 产品代号	type 型号
1SAZ721201R1005	TF42-0.13	1SAZ741201R1005	TF42-0.13B
1SAZ721201R1008	TF42-0.17	1SAZ741201R1008	TF42-0.17B
1SAZ721201R1009	TF42-0.23	1SAZ741201R1009	TF42-0.23B
1SAZ721201R1013	TF42-0.31	1SAZ741201R1013	TF42-0.31B
1SAZ721201R1014	TF42-0.41	1SAZ741201R1014	TF42-0.41B
1SAZ721201R1017	TF42-0.55	1SAZ741201R1017	TF42-0.55B
1SAZ721201R1021	TF42-0.74	1SAZ741201R1021	TF42-0.74B
1SAZ721201R1023	TF42-1.0	1SAZ741201R1023	TF42-1.0B
1SAZ721201R1025	TF42-1.3	1SAZ741201R1025	TF42-1.3B
1SAZ721201R1028	TF42-1.7	1SAZ741201R1028	TF42-1.7B
1SAZ721201R1031	TF42-2.3	1SAZ741201R1031	TF42-2.3B
1SAZ721201R1033	TF42-3.1	1SAZ741201R1033	TF42-3.1B
1SAZ721201R1035	TF42-4.2	1SAZ741201R1035	TF42-4.2B
1SAZ721201R1038	TF42-5.7	1SAZ741201R1038	TF42-5.7B
1SAZ721201R1040	TF42-7.6	1SAZ741201R1040	TF42-7.6B
1SAZ721201R1043	TF42-10	1SAZ741201R1043	TF42-10B
1SAZ721201R1045	TF42-13	1SAZ741201R1045	TF42-13B
1SAZ721201R1047	TF42-16	1SAZ741201R1047	TF42-16B
1SAZ721201R1049	TF42-20	1SAZ741201R1049	TF42-20B
1SAZ721201R1051	TF42-24	1SAZ741201R1051	TF42-24B
1SAZ721201R1052	TF42-29	1SAZ741201R1052	TF42-29B
1SAZ721201R1053	TF42-35	1SAZ741201R1053	TF42-35B
1SAZ721201R1055	TF42-38	1SAZ741201R1055	TF42-38B

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心

CQC 中国质量认证中心