



Certificate of Compliance

Certificate: 2648238 (098793_0_000)

Master Contract: 183691

Project: 70072547

Date Issued: 2016-04-07

Issued to: ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82
Heidelberg, Baden-Württemberg 69123
GERMANY
Attention: Eric Englert

The products listed below are eligible to bear the CSA Mark shown



Issued by: Ramana
Tangirala
Ramana Tangirala

PRODUCTS

CLASS - C143201 - CIRCUIT BREAKERS-Moulded Case Type

CLASS - C143701 - CIRCUIT BREAKERS-Accessories

PART -A:

- **Model "SU20xM" followed by suffixes**, 0.2A to 63A, 1 to 4 poles, Common-Trip, 40°C Uncompensated, 1 to 3 poles rated 480V ac max and 96V dc max,; Tripping Characteristic: K B, C, D and Z, HIC 10kA, 240V ac, 48V dc and 96V dc.

Current and Voltage Ratings:

Characteristic K:

0.2A to 35A, 277V ac (one pole), 480Y/277Vac (multi-pole);

0.2A to 63A, 240V ac (one pole); 240Vac(multi-pole); 48Vdc (one pole), 96Vdc (2 pole)

Characteristic B and C:

0.5A to 40A, 277V ac (one pole), 480Y/277Vac (multi-pole);

0.5A to 63A, 240V ac (one pole); 240Vac(multi-pole); 48Vdc (one pole), 96Vdc (2 pole)

Characteristic D:

0.5A to 35A; 277V ac (one pole), 480Y/277Vac (multi-pole);



Certificate: 2648238
Project: 70072547

Master Contract: 183691
Date Issued: 2016-04-07

0.5A to 63A, 240V ac (one pole); 240Vac(multi-pole); 48Vdc (one pole), 96Vdc (2 pole)

Characteristic Z:

0.5A to 40A; 277V ac (one pole), 480Y/277Vac (multi-pole);
0.5A to 63A, 240V ac (one pole); 240Vac(multi-pole); 48Vdc (one pole), 96Vdc (2 pole)

PART-B:

Breaker Accessories for Models SU20xM:

- Auxiliary Contact **S2C-H6RU** and Alarm (Signal) contact **S2C-S6RU** with ratings - 1A, 480V ac; 2A, 277V ac; 1.5A, 125V dc, 2A, 60V dc and 4A, 24V dc;
- Shunt Trip, **S2C-A1U**, 12-60V ac/dc; **S2C-A2U**, 110-415V ac and 110-250V dc.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and
Circuit-Breaker Enclosures.