



产品认证证书

证书编号: CQC2017010304993562

申请人名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

制造商名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称及地址

ABB Stotz-Kontakt GmbH (V054919)
Eppelheimer Strasse 82 69123 Heidelberg Germany

产品名称和系列、规格、型号

家用及类似用途机电式接触器

ESB40-xxN, ESB63-xxN, EN40-xxN; Ui: 500V; Ith: 63A (ESB63-xxN), 40A (ESB40-xxN, EN40-xxN); ESB40-xxN, EN40-xxN:
AC-7a: Ue/Ie: AC400V/40A(NO), AC400V/30A(NC); ESB63-xxN: AC-7a: Ue/Ie: AC400V/63A(NO),
AC400V/30A(NC); ESB40-xxN, EN40-xxN: AC-7b: Ue/Ie: AC400V/22A(NO); ESB63-xxN: AC-7b: Ue/Ie: AC400V/30A(NO); Us:
12V, 24V, 42V, 48V, 110V, 230V, 240V, 400V, 415V 50/60Hz/DC; DC24V; IP20; 极数: 4P; 型号解释详见附件

产品标准和技术要求

GB/T 17885-2016

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462143-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 09 月 02 日 有效期至: 2022 年 08 月 10 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任:

陆楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0356104



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2017010304993562

NAME AND ADDRESS OF THE APPLICANT

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE FACTORY

ABB Stotz-Kontakt GmbH (V054919)
Eppelheimer Strasse 82 69123 Heidelberg Germany

PRODUCT NAME, MODEL AND SPECIFICATION

Electromechanical contactors for household and similar purposes

ESB40-xxN, ESB63-xxN, EN40-xxN; Ui: 500V; Ith: 63A(ESB63-xxN), 40A(ESB40-xxN, EN40-xxN); ESB40-xxN, EN40-xxN:
AC-7a: Ue/Ie: AC400V/40A(NO), AC400V/30A(NC); ESB63-xxN : AC-7a: Ue/Ie: AC400V/63A(NO),
AC400V/30A(NC); ESB40-xxN, EN40-xxN: AC-7b: Ue/Ie: AC400V/22A(NO); ESB63-xxN : AC-7b: Ue/Ie: AC400V/30A(NO); Us:
12V, 24V, 42V, 48V, 110V, 230V, 240V, 400V, 415V 50/60Hz/DC; DC24V; IP20; Poles: 4P;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 17885-2016

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462143-2019 .

Valid from: Sep.02,2020

Valid until: Aug.10,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0356104



产品认证证书

附录

第 1 页 共 2 页

证书编号: CQC2017010304993562

纸 号: 356104

型号解释:

ESB	40	-	22	N	-	xx
1	2		3	4		5

1. Model name

ESB - standard model

EN - with additional manual operation

2. Basic type 40

3. Contact variants of the contactor

40 4 NO

22 2 NO / 2 NC

20 2 NO

30 3 NO

31 3 NO / 1 NC

11 1 NO / 1 NC

02 2 NC

4. ESB series suffix

N - upgraded version

5. optional for marketing or customer, letter, number and symbol, DC-B

注: 此附录与证书同时使用时有效。

主任: _____

陆梅

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2017010304993562

纸号: 356104

Type	Contacts	Remarks
EN40-40N/EN40-40	4 NO	
EN40-20N	2 NO	
EN40-30N	3 NO	
EN40-31N	3 NO + 1NC	
ESB40-40N	4 NO	
ESB40-22N	2 NO + 2 NC	
ESB40-20N	2 NO	
ESB40-30N	3 NO	
ESB40-31N	3 NO + 1NC	
ESB63-40N	4 NO	
ESB63-22N	2 NO + 2 NC	
ESB63-20N	2 NO	
ESB63-30N	3 NO	
ESB63-31N	3 NO + 1NC	
ESB63-11N	1 NO + 1 NC	

注: 此附录与证书同时使用时有效。

主任:

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>