



中国国家强制性产品认证证书

证书编号: 2004010304112235

委托人名称、地址

ABB France
2 rue d'Arsonval 69680 Chassieu France

生产者(制造商)名称、地址

ABB France
2 rue d'Arsonval 69680 Chassieu France

生产企业名称、地址

ABB Bulgaria EOOD - Rakovski branch
BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial Road 1, nr,14-18

产品名称和系列、规格、型号

交流接触器
AL30-30,AL40-30,TAL30-30,TAL40-30,TAL30-30...RT,TAL40-30...RT;详见参数附件

产品标准和技术要求

GB/T 14048.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,特发此证。

发证日期: 2020年08月07日有效期至: 2021年08月03日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期: 2004年03月29日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询
经中国合格评定国家认可委员会认可 CNAS C001-P



主任: 陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2004010304112235

NAME AND ADDRESS OF THE APPLICANT

ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE FACTORY

ABB Bulgaria EOOD – Rakovski branch
BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski
Industrial Zone, 14 Industrial Road 1, nr,14-18

PRODUCT NAME, MODEL AND SPECIFICATION

AC Contactor
AL30-30,AL40-30,TAL30-30,TAL40-30,TAL30-30...RT,TAL40-30...RT;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.4-2010

This is to certify that the above mentioned product(s) complies with therequirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Aug.07,2020**Valid until:**Aug.03,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Mar.29,2004

The certificate information is available through CNCA's website: www.cnca.gov.cn
Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录:

第 1 页 共 3 页

证书编号: 2004010304112235

纸号: 2658772

AL30-30, AL40-30, TAL30-30, TAL40-30, TAL30-30...RT, TAL40-30...RT

Ui: 1000V (690V for RT);

Ith: 65A;

(T)AL30:

AC-1: Ue/Ie: 690V/55A;

AC-3: Ue/Ie: 220/230/240V/33A, 380/400/415/440V/32A, 500V/28A, 690V/18A;

AC-4: Ue/Ie: 220/230/240V/33A, 380/400/415/440V/32A, 500V/23A, 690V/15A;

AC-8a: Ue/Ie: 400V/40A;

(T)AL30RT:

AC-1: Ue/Ie: 690V/50A;

AC-3: Ue/Ie: 220/230/240V/33A, 380/400/415/440V/32A, 500V/28A, 690V/18A;

AC-4: Ue/Ie: 220/230/240V/33A, 380/400/415/440V/32A, 500V/23A, 690V/15A;

AC-8a: Ue/Ie: 400V/40A;

(T)AL40(RT):

AC-1: Ue/Ie: 690V/60A;

AC-3: Ue/Ie: 220/230/240V/40A, 380/400/415V/37A,

440V/ AL40:32A /TAL40, TAL40-RT:37A, 500V/33A, 690V/21A;

AC-4: Ue/Ie: 220/230/240V/33A, 380/400/415/440V/32A, 500V/23A, 690V/18A;

AC-8a: Ue/Ie: 400V/50A;

Us: DC12V, DC24V, DC48V, DC110V, DC125V, DC220V, DC240V,

DC17-32V, DC25-45V, DC36-65V, DC42-78V, DC50-90V, DC77-143V, DC90-150V;

极数: 3P;

IP20(IP10 for TAL RT);

配用辅助触头: (本体)

Ith: 16A;

注: 此附录与证书同时使用时有效



主任:

陆梅



中国质量认证中心



中国国家强制性产品认证证书

附录:

第 2 页 共 3 页

证书编号: 2004010304112235

纸号: 2658772

AC-15: Ue/Ie: 24-127V/6A, 220-240V/4A, 380-440V/3A, 500-690V/2A;

DC-13: Ue/Ie: 24V/6A, 48V/2.8A, 72V/2A, 110-125V/1.1A, 220-250V/0.55A;

1NO, 1NC

注: 此附录与证书同时使用时有效



主任:

陆梅



中国质量认证中心



中国国家强制性产品认证证书

附录:

第 3 页 共 3 页

证书编号: 2004010304112235

纸号: 2658772

型号的解释:

AL	30	30	10	RT	
I	II	III	IV	V	VI

I - Main designation:

AL - with standard control supply voltage Us

TAL - with wide range control supply voltage Us

II - Rated current

30, 40

III - Main Pole Construction

30 - 3 Normally Opened and 0 Normally Closed main poles.

IV - Auxiliary Pole Construction

01 - 1 normally closed auxiliary pole.

10 - 1 Normally opened auxiliary pole.

22 - 2 Normally Opened and 2 Normally Closed auxiliary poles

V - Terminals

Blank = screw terminals

RT = Ring-Tong terminals

VI - Coil code

Coil code	Control voltage	Coil code	Control voltage
80	12Vdc	51	17-32Vdc
81	24Vdc	52	25-45Vdc
83	48Vdc	54	36-65Vdc
86	110Vdc	58	42-78Vdc
87	125Vdc	55	50-90Vdc
88	220Vdc	62	77-143vdc
89	240Vdc	66	90-150Vdc

注: 此附录与证书同时使用时有效



主任:

陆梅



中国质量认证中心