



中国国家强制性产品认证证书

证书编号：2004010304138315

委托人名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产者（制造商）名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产企业名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

产品名称和系列、规格、型号

接触器

AE50-30, TAE50-30, AE63-30, AE75-30, TAE75-30; 详见参数附件

产品标准和技术要求

GB/T14048. 4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。

发证日期：2017年08月21日 有效期至：2022年08月21日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2004年12月28日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2004010304138315

NAME AND ADDRESS OF THE APPLICANT

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE FACTORY

ABB France
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

PRODUCT NAME, MODEL AND SPECIFICATION

Contactor
AE50-30, TAE50-30, AE63-30, AE75-30, TAE75-30; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Aug.21,2017

Valid until: Aug.21,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Dec.28,2004

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2004010304138315

纸号: 1778890

AE50-30,TAE50-30,AE63-30,AE75-30,TAE75-30

Ui:1000V;

AE50,TAE50:Ith:100A;

AE63,AE75,TEA75:Ith:125A;

AE50-30,TAE50-30:

AC-1:Ue/Ie:690V/100A;

AC-3,AC-4:Ue/Ie:220-230-240V/53A,380-400/415V/50A,440/500V/45A,690V/35A;

AC-8a:Ue/Ie:400V/63A;

AE63-30:

AC-1:Ue/Ie:690V/115A;

AC-3,AC-4:Ue/Ie:220-230-240/380-400/415/440V/65A,500V/55A,690V/43A;

AC-8a:Ue/Ie:400V/85A;

AE75-30,TAE75-30:

AC-1:Ue/Ie:690V/125A;

AC-3,AC-4:Ue/Ie:220-230-240/380-400/415V/75A,440V/70A,500V/65A,690V/46A;

AC-8a:Ue/Ie:400V/95A;

Us:DC24V,DC48V,DC110V,DC220V(for AE);

DC17-32V,DC50-90V,DC77-143V,DC152-254V(for TAE);

3P;IP10

型号的解释:

(T)AE 50 30 00

注: 此附录与证书同时使用时有效。



主任:



中国质量认证中心



中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2004010304138315

纸号: 1778890

I II III IV V

I - Main designation : AE or TAE (T : with large coil voltage)

II - Range size

50, 63, 75

III - Main Pole Construction

30 - 3 Normally Opened and 0 Normally Closed main poles.

IV - Auxiliary Pole Construction

00 - No auxiliary pole provided.

11 - One Normally Opened and one Normally Closed auxiliary poles.

V - Coil code

See table 1

List of type

Designation
AE50-30-00 + coil voltage
AE50-30-11 + coil voltage
TAE50-30-00 + coil voltage
TAE50-30-11 + coil voltage
AE63-30-00 + coil voltage
AE63-30-11 + coil voltage
AE75-30-00 + coil voltage
AE75-30-11 + coil voltage
TAE75-30-00 + coil voltage
TAE75-30-11 + coil voltage

注: 此附录与证书同时使用时有效。



主任:



中国质量认证中心