A
A/D-conversion module *7–10*
A1A2_BS *6–233*, *6–236*, *6–293*, *6–324*
A1A2_DC *6–233*, *6–237*, *6–296*, *6–325*
AB_TRAFO *6–233*, *6–235*, *6–288*, *6–322*
ABC_BC *6–233*, *6–235*, *6–282*, *6–320*
ABC_LINE *6–233*, *6–235*, *6–275*, *6–318*
active group *5–7*
active power P *6–589*
ADM *7–10*
AND *5–27*
apparatus control *6–145*
AR *6–463*, *6–493*
AR01-CBCLOSED *6–466*, *6–496*
AR01-CBREADY *6–467*, *6–496*
AR01-CLOSECB *6–468*, *6–497*
AR01-INHIBIT *6–467*, *6–496*
AR01-INPROGR *6–467*
AR01-OFF *6–466*, *6–496*
AR01-ON *6–466*, *6–496*
AR01-P1PH *6–468*, *6–497*
AR01-P3PH *6–468*, *6–497*
AR01-PLCLOST *6–467*, *6–496*
AR01-READY *6–467*, *6–497*
AR01-SP1 *6–467*
AR01-START *6–466*, *6–496*
AR01-SYNC *6–467*, *6–496*
AR01-TP1 *6–467*
AR01-TP2 *6–467*, *6–497*
AR01-TPTRIP *6–467*, *6–497*
AR01-TRSOTF *6–467*, *6–497*
AR01-UNSUC *6–468*, *6–497*
AR01-WAIT *6–467*, *6–497*
AR01-WFMASTER *6–468*, *6–497*
ARXX *3–20*
ASD *6–57*
automatic *6–150*, *6–190*
auto-reclosing *6–188*, *6–463*, *6–493*

B
back-up panel *6–182*
back-up trip *6–55*
baud rate *4–16*
BAxx - signal name *6–195*, *6–203*
BAYCON *6–153*, *6–154*, *6–157*
BAYCONA *6–154*, *6–195*, *6–205*, *6–226*
BAYCONB *6–154*, *6–196*, *6–207*
BAYCONC *6–154*, *6–197*, *6–208*
BAYCOND *6–154*, *6–198*, *6–211*
BAYCONE *6–154*, *6–199*, *6–214*
BAYCONF *6–154*, *6–200*, *6–216*, *6–226*
BB_ES *6–233*, *6–237*, *6–299*, *6–326*
BBxx - signal name *6–196*
BCxx - signal name *6–197*
BDxx - signal name *6–198*
BExx - signal name *6–199*
BFP *3–11*, *6–53*
BFxx - signal name *6–200*
BH_CONN *6–233*, *6–312*, *6–331*
BH_LINE_A *6–233*, *6–308*, *6–329*
BH_LINE_B *6–233*, *6–314*, *6–332*
BIM *5–16*, *7–16*
binary in/out module *7–15*
binary input module *5–16*, *7–16*
binary output module *5–17*, *7–17*
BKxx - signal name *6–204*
BLKCON *6–153*, *6–166*
BLKCONK *6–155*, *6–204*, *6–225*
BLKCONL *6–155*, *6–205*, *6–226*
block functions *4–20*
blocking *6–151*
BLxx - signal name *6–205*
BOM *5–17*, *7–17*
breaker-and-a-half *6–239*, *6–253*
breaker-failure protection *6–53*
built-in mmi *6–183*
busbar earthing switch *6–237*, *6–266*
bus-coupler bay *6–235*, *6–246*
bus-section breaker *6–236*, *6–254*
bus-section disconnector *6–237*, *6–258*
buttons *4–26*

C
CAN bus *7–11*
CDxx-signal name *6–339*
CMxx-signal name *6–544*
COMBITEST *4–19*
COMCON *6–153*, *6–154*, *6–162*, *6–201*, *6–219*, *6–226*
command dialogue *6–337*
command function *6–335*
command outputs *6–190*
command supervision *6–151*
commissioning *4–18*
configurable logic *5–25*
configuration *4–17*, *4–36*
configuration mode *4–17*
cover *4–5*
COxx - signal name *6–201*
cut-out sizes *4–9*

D
DAR *6–463*, *6–493*
data part *6–577*
DB_BUS_A *6–233*, *6–238*, *6–299*, *6–326*
DB_BUS_B *6–233*, *6–238*, *6–305*, *6–328*

DB_LINE *6–233*, *6–238*, *6–301*, *6–327*
DBLL *6–343*, *6–369*, *6–388*, *6–410*, *6–441*
Dead bus live line *6–343*, *6–369*, *6–388*, *6–410*, *6–441*
Dead line live bus *6–343*, *6–369*, *6–388*, *6–410*, *6–441*
dead-band supervision *6–591*, *6–609*
diameter *6–239*
directional comparison logic *6–97*
DISTREP CLEARED *4–22*
disturbance overview *6–558*
disturbance report *6–557*, *6–563*
disturbance summary *6–558*
DLD *3–9*
DLLB *6–343*, *6–369*, *6–388*, *6–410*, *6–441*
double breaker *6–238*, *6–252*
double busbar *6–235*
DREP *3–23*
DSP *7–12*

E
earthing wire *4–11*
electrical terminals *4–11*
energizing check *6–367*, *6–385*
event function *6–545*
EVR *3–23*
EVxx-signal name *6–549*, *6–550*
extremely inverse *6–88*

F
fault locator *6–585*
fault tracing *4–21*
ferrule *4–13*
fibre optic *4–14*
filter *7–10*
flush mounting *4–8*, *4–9*
FreqDiff *6–341*, *6–367*, *6–388*, *6–408*, *6–438*
frequency f *6–589*
front communication *4–15*
FUSE *3–17*

G
gasket *4–5*
GRP *3–7*

H
hardware design *7–9*
header *6–577*
HMI *3–7*
HSAR *6–463*, *6–493*
human machine interface *3–7*
hysteresis *6–591*, *6–609*

I
I/O system *5–15*
IAxx - signal name *6–301*
IBxx - signal name *6–299*
ICxx - signal name *6–305*
identifiers *5–4*
IEC 870-5-103 *3–22*
IExx - signal name *6–288*
IFxx - signal name *6–275*
IGxx - signal name *6–282*
IHxx - signal name *6–293*
IIxx - signal name *6–296*
IJxx - signal name *6–299*
IKxx - signal name *6–312*
ILxx - signal name *6–308*
IMxx - signal name *6–314*
indications *6–573*
input/output module *5–18*, *7–14*
installation *4–5*
instantaneous o/c protection *6–65*, *6–75*
INT-- CPUFAIL *4–21*
INT-- CPUWARN *4–21*
INT-- WARNING *4–21*
INT--ADC *4–21*
integrating dead-band *6–591*, *6–609*
interlocking *6–184*, *6–229*
internal clock *5–3*
internal events *4–22*
INT--FAIL *4–21*
INT--IOyy *4–21*
INT--RTC *4–21*
INT--TSYNC *4–21*
IOC *3–10*
IOM *5–18*, *7–15*
IOP (I/O position) *5–20*

L
led indications *6–573*
limit time *6–560*
LNT *4–17*
LO *3–22*
local control panel *6–182*
logarithmic inverse *6–88*
LON *3–18*, *3–24*, *4–15*, *7–21*
LON Network Tool *4–17*
LOV *3–16*

M
mA input module *5–18*, *6–607*
main processing module *7–11*
maintenance *4–24*
man machine interface *7–19*
manual trig *6–562*
manual updating *6–150*
mean values *6–589*
measuring range *6–590*

mechanical installation *4–5*
memory *6–557*, *6–575*
menu tree *4–41*
MicroSCADA *3–28*
MIM *5–18*, *6–618*
MMI *4–25*, *7–19*
MMI--BLOCKSET *4–15*
mounting angles *4–5*
mounting kits *4–5*
MPM *7–11*

N
normal inverse *6–88*

O
operator place *6–146*, *6–177*
optical fibre *3–27*, *7–21*
OR *5–27*
overcurrent protection *6–65*, *6–75*
overvoltage protection *6–109*

P
PD *3–11*
PhaseDiff *6–341*, *6–367*, *6–388*, *6–408*, *6–438*
phasors *6–600*
pole discordance *6–189*
post-fault recording time *6–560*
power supply module *7–12*
pre-fault recording time *6–560*
protection with App. Control *6–189*
PSM *7–12*
pulse *5–30*

R
rack mounting *4–5*
reactive power Q *6–589*
receiving *4–5*
reclosing counters *6–465*, *6–495*
reclosing programs *6–469*
recording capacity *6–575*
recording times *6–560*
remote communication *4–16*
remote-control *6–182*
repair instruction *4–23*
reservation *6–148*, *6–170*
restricted settings *5–11*
retrip *6–55*, *6–58*
RTXP 24 *4–19*

S
sampling frequency *7–10*
SAxx - signal name *6–202*
SBxx - signal name *6–203*
screw terminals *4–10*
SCxx - signal name *6–204*
sealing strip *4–5*
secondary injection test *4–19*
self-supervision *4–21*
SequenceNo *6–563*
serial communication module *4–15*, *7–21*
SETTING CHANGED *4–22*
setting group *5–7*
setting restriction *5–12*
side-by-side mounting *4–7*
signal processing module *7–12*
single breaker *6–240*, *6–246*, *6–251*
slave number *4–16*
socket *4–13*
SPA *3–22*, *3–24*, *4–15*, *7–21*
SPM *7–12*
station mmi *6–179*
storage *4–5*
SWICON *6–155*, *6–163*
SWICONA *6–155*, *6–202*, *6–221*, *6–226*
SWICONB *6–155*, *6–203*, *6–222*, *6–227*
SWICONC *6–155*, *6–204*, *6–224*, *6–227*
synchro-check *6–152*, *6–184*, *6–341*, *6–367*, *6–388*, *6–408*, *6–438*
SYNX *3–19*

T
terminal identification *5–3*
test mode *4–18*, *6–567*
TEST-INPUT *4–18*
timer *5–28*
TOC *3–10*
transfer busbars *6–235*
transformer bay *6–235*, *6–251*
transformer input module *7–9*
trig signals *6–562*
TRIP *3–21*
tripping logic *6–517*
TRM *7–9*
TUV *3–14*

V
very inverse *6–88*
voltage connector *4–11*

W
wall mounting *4–10*

X
XOR *5–31*