



中国国家强制性产品认证证书

证书编号: 2007010304256684

委托人名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

生产者(制造商)名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称、地址

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

产品名称和系列、规格、型号

交流接触器

AF580-30-*, AF750-30-*, AFS580-30-*, AFS750-30-*; 详见参数附件

产品标准和技术要求

GB/T14048.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2019 年 05 月 28 日 有效期至: 2022 年 06 月 20 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2007 年 11 月 28 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2007010304256684

NAME AND ADDRESS OF THE APPLICANT

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE MANUFACTURER

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE FACTORY

ABB AB, Control Products
Motorgrand 20, 72161 Vasteras, Sweden

PRODUCT NAME, MODEL AND SPECIFICATION

AC Contactor
AF580-30-*, AF750-30-*, AFS580-30-*, AFS750-30-*; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.28,2019

Valid until: Jun.20,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Nov.28,2007

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2007010304256684

纸 号: 2292734

AF580-30-**-*, AF750-30-**-*, AFS580-30-**-*, AFS750-30-**-*

Ui: 1000V;

Uimp: 8kV;

Ith: AF580: 800A, AF750: 1050A;

AF(S) 580-30-**-* :

Ue/Ie:

AC-3: 220-240V/230V/380-400V/415V/440V/500V/580A,

660-690V/500A, 1000V/250A;

AC-1: 415V/690V/1000V/800A;

AF(S) 750-30-**-* :

Ue/Ie:

AC-3: 220-240V/230V/380-400V/415V/440V/500V/750A, 660-690V/650A, 1000V/300A;

AC-1: 415V/690V/1000V/1050A;

极数: 3P;

Us: 100-250VAC/DC, 48-130VAC/DC, 24-60VDC, 250-500VAC/DC (50/60Hz);

配用辅助触头:

CAL18-11, CAL18-11B, CAL18-11RT: 1NO1NC, 2NO2NC;

Ith: 16A;

AC-15: Ue/Ie: 24-127V/6A, 220-240V/4A, 280-440V/3A, 500-690V/2A;

DC-13: Ue/Ie: 24V/6A, 48V/2.8A, 72V/1A, 125V/0.55A, 250V/0.3A;

CEL18-10, CEL18-01: 1NO, 1NC;

Ith: 0.1A;

AC-14: Ue/Ie: 24-125V/0.1A,

DC-12: Ue/Ie: 24-110V/0.1A

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2007010304256684

纸 号: 2292734

型号解释:

Full type 型号		AF750-30-11-68			
		1 (AF580)	2 (30)	3 (11)	4 (68)
Position 位置	Product 产品	√	√		
	package label 包装标签	√	√	√	√

1 = Name of series and size of contactor 接触器系列名称及大小

AF580 = Basic model 基本型号

AFS580 = Safety contactor 安全接触器

AF580 = Basic model 基本型号

AFS580 = Safety contactor 安全接触器

2: Number of main contacts 主触头数量

30 = 3 NO- and 0 NC-contacts

3: Number of NO and NC auxiliary contacts 辅助触头(CAL18-11, CEL18-01 or CEL18-10)

00 = without auxiliary contact 无辅助触头

11 = 1 NO- and 1 NC-contacts (side mounted 侧装 CAL18-11)

22 = 2 NO- and 2 NC-contacts (side mounted 侧装 2 pieces CAL18-11)

01 = 0 NO- and 1 NC-contacts (side-mounted 侧装 CEL18-01)

10 = 1 NO- and 0 NC-contacts (side-mounted 侧装 CEL18-10)

12 = 1 NO- and 2 NC-contacts (side-mounted 侧装 CAL18-11 and CEL18-10 only for AFS-contactor 仅对安全接触器)

4: Control supply voltage code 线圈代号

68: Us = 24-60V d.c. with PLC-control

69: Us = 48-130V a.c./d.c. with PLC-control

70: Us = 100-250V a.c./d.c. with PLC-control

71: Us = 250-500V a.c./d.c. with PLC-control

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

变更结论 Modification Approval

证书编号 Certificate No. : 2007010304256684

申请编号 Application No. : A2019CCC0304-3141270

申请人(委托人) Applicant: ABB AB, Control Products / ABB AB, Control Products

证书编号 Certificate No.(变更前 Original): 2007010304256684

变更产品名称: 交流接触器

Name of Product Modified: AC Contactor

变更情况 Situation of Modification (见下表 See table below):

序号	项目 Item	变更前 Original	变更后 Present
1	安全件壳体(盖,基座) 型号规格/牌号变更 (增加原材料)	Latamid 6 H2 G/20 V2 HF BMC UP 46-12 (IDI) BMC RF 654-20	Latamid 6 H2 G/20 V2 HF Ultramid Type KR4460 BMC RF 654-20 BMC UP 46-12
2	安全件壳体(盖,基座) 供应商增加	ABB AB Control HBG Tecno Press AB	ABB AB, Control Products HBG Tekno Press AB Ma.J Plastic Product CO.LTD
3	安全件灭弧罩供应商 增加	Gerdins Cable Systems Sp. Zoo	AQ Wiring Systems STG Sp. z o.o Jiangmen Electronics 8 Factory Co Ltd
4	产品型号增加	AF580-30-*, AF750-30-*	AF580-30-*, AF750-30-*, AFS580- 30-*, AFS750-30-*

现批准以上变更。

Above Modification is approved. The present will replace the original.

批准日期 (Date): 2019 年 05 月 28 日

第 1 页 / 共 1 页



主任:

陆梅



中国质量认证中心