

HOTFIX RELEASE NOTE

PCM600 2.7

Hotfix Rollup 20161222



Dear PCM600 User

A hotfix rollup package for Protection and Control IED Manager PCM600 2.7 has been released.

The hotfix 20161222 for PCM600 2.7 is solving the following issues:

- Included optional IdName attribute to the exported SCL files in all engineering scenarios.
- Improved GOOSE logic saving for devices supporting GOOSE logic mapping in Signal Matrix.
- Added warning messages to IEC 61850 structure mapping for better usability in Flexible product naming.
- Improved robustness of project conversion in case of faulty old PCM600 projects.
- Introduced better support for IEC 61850 parameters in Flexible Product Naming.
- Added support for reading GOOSE mapping to an empty PCM600 project with 64-bit PCM600.
- Added possibility to use Scheduler with devices including enhanced security features.

This hotfix rollup includes also previously released hotfix and hotfix rollups for PCM600 2.7:


-
- Hotfix 20160311
- Hotfix Rollup 20160603
- Hotfix Rollup 20160704

Note: If the previously released hotfix packages for PCM600 2.7 are already installed, then only the new hotfixes will be applied. If earlier hotfix for PCM600 2.7 has not been installed, then this rollup package will apply all the updates.

The hotfix 20161222 for PCM600 2.7 is available via the PCM600 Update Manager. It contains the following file:

- PCM600 2.7 Rollup 20161222.exe

We recommend the installation of this Rollup 20161222 when using PCM600 2.7.



For more information, please contact your local ABB representative.

ABB constantly examines both operational and new software to identify possible faults or product improvements, issuing hotfixes where appropriate. We apologize for any inconvenience the identified faults have caused.

Kind regards,
Raghuvendra Singh
Global Product Manager
ABB

Henry Niveri
Product Manager
ABB

ABB Oy
Medium Voltage Products,
Distribution Automation
P.O. Box 699
FI-65101 VAASA, Finland
Phone +358 10 22 11
Fax +358 10 22 41599
<http://abb.com/mediumvoltage>

ABB AB
Grid Automation Products
SE-721 59 Vasteras, Sweden
Phone +46 (0) 21 32 50 00
Fax +46 (0) 21 14 69 18
<http://abb.com/substation-automation>

We reserve the right to make technical changes or modify the contents of this document without prior notice. With regard to purchase orders, the agreed particulars shall prevail. ABB does not accept any responsibility whatsoever for potential errors or possible lack of information in this document.

We reserve all rights in this document and in the subject matter and illustrations contained therein. Any reproduction, disclosure to third parties or utilization of its contents – in whole or in parts – is forbidden without prior written consent of ABB. Copyright © 2016 ABB
All rights reserved