



Test Report				Date of issue: 4.6.2014							
				Serial No.: 3GF11094416							
				Type: M3KP 160MLC 6 IMB3/IM1001							
				Product Code: 3GKP163430-ADH							
				Protection type: Ex de IIB T4 Gb							
				Cert. No.: LCIE 11 ATEX 3087X / IECEx LCI 09.0008X							
Rating:				V	Hz	kW	r/min	A	cos φ	Duty	
3~Motor				690	Y 50	14	969	17,5	0,75	S1	
Insul.cl.F				400	D 50	14	969	30,2	0,75	S1	
IP55				415	D 50	14	971	29,9	0,73	S1	
Eff class IE1				50Hz : IE2 - 89.2(100%) - 89.4(75%) - 88.0(50%)							
Resistance				Ambient: 21,0 °C			Insulation resistance at 47,5 °C				
Line							3000 MΩ			1000 V	
U ₁ - V ₁				0,40000 Ω							
U ₁ - W ₁				0,40020 Ω							
V ₁ - W ₁				0,40020 Ω							
							High-voltage test winding 2900 V			1 s	
Test	Torque [Nm]	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	n[r/min]	cos φ	η [%]		
No load test		400,0 D	50	17,3	0,65		998	0,05			
Locked rotor test		84,5 D	50	30,2	1,65		0	0,37			
Thermal test (100% load)	138,0	400,0 D	50	30,1	15,7	14,0	973	0,75	89,1		
Partial load points:											
~75% load	103,3	400,0 D	50	25,2	11,7	10,5	981	0,67	89,4		
~50% load	68,5	400,0 D	50	20,9	7,92	7,00	987	0,55	88,4		
~25% load	34,4	400,0 D	50	17,9	4,23	3,50	993	0,34	82,8		
Temperature rise at rated load.				°C	K	Method		Measurement method			
Stator winding :				73,6	73,6	1		1 Resistance			
Frame :				35,8	35,8	2		2 Thermometer			
Bearing D-end :				39,7	39,7	2		3 Thermocouples			
Rotor :				92,0	92,0	3					
Ambient Temperature :				25,0	25,0	2					
Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss.											
On behalf of customer											
On behalf of manufacturer				Date of test		14.2.2012					
Tested by ABB Oy, Motors and Generators, Vaasa, Finland							Telephone +358 10 2211 Telefax +358 10 22 47372				

Computer print-out valid without signature.

ABB, Motors and Generators
www.abb.com/motors&generators