



Ref. Certif. No.

CN49526

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch-disconnectors
Name and address of the applicant	ABB S.P.A. - ABB SACE Division Via Pescaria 5, 24123 Bergamo Italy
Name and address of the manufacturer	ABB S.P.A. - ABB SACE Division Via Pescaria 5, 24123 Bergamo Italy
Name and address of the factory	ABB S.P.A. - ABB SACE Division Via Enrico Fermi 14, IT-03100 Frosinone Italy
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	See the Appendix
Trademark (if any)	ABB
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	E2.2B/MS, E2.2N/MS, E2.2H/MS, E2.2H/E9/MS, E2.2H/E/MS;
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2007 (5th Edition) + AMD1:2010 + AMD2:2014; IEC 60947-3:2008(3rd Edition) + AMD 1:2012 + AMD 2:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2019CQC-088018

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Mar.03,2020

Signature: 
Lu Mei

CB 0054897

E2.2B/MS, E2.2N/MS, E2.2H/MS, E2.2H/E9/MS, E2.2H/E/MS;

Uimp: 12kV;

Ui: 1000V(E2.2B/MS, E2.2N/MS, E2.2H/MS), 1250V(E2.2H/E9/MS, E2.2H/E/MS);

Ith: 2000A(E2.2B/MS), 2500A(E2.2N/MS, E2.2H/MS, E2.2H/E9/MS, E2.2H/E/MS);

Ue: AC440V, AC690V(E2.2B/MS, E2.2N/MS, E2.2H/MS);

AC900V(E2.2H/E9/MS, E2.2H/E/MS); AC1000/1140V(E2.2H/E/MS);

Ie: 1600A, 2000A(E2.2B/MS);

800A, 1000A, 1250A, 1600A, 2000A, 2500A(E2.2N/MS, E2.2H/MS, E2.2H/E/MS);

1250A, 1600A, 2000A, 2500A(E2.2H/E9/MS);

Ue		E2.2B/MS	E2.2N/MS	E2.2H/MS	E2.2H/E9 MS	E2.2H/E MS
440 - 690Vac	Icw 1s [kA]	42	66	85	-	-
900Vac		-	-	-	65	65
1000 - 1140Vac		-	-	-	-	50
440 - 690Vac	Icm [kA]	88	145	187	-	-
900Vac		-	-	-	143	143
1000 - 1140Vac		-	-	-	-	105

Utilization category:AC-23A;

Poles:3P,4P;

50/60Hz;

Additional information (if necessary)

Date:

Mar.03,2020

Signature:



Lu Mei