

Driver JDF300 FF

Field Indicator

Contents

1	Device - Revision Record - What is new?	2
1.1	Hardware ID: 0008.....	2
1.2	Firmware.....	2
1.3	Device (latest SW compatibility status).....	2
1.4	Supported devices.....	2
1.5	Cyber Security info	2
1.5.1	ABB recommendation	2
1.6	Licensing.....	2
2	EDD/CF.....	3
2.1	EDD/CF Version record - What is new?	3
2.2	Supported Languages	3
2.3	Requirements.....	3
2.3.1	EDD Host application / compatibility	3
2.4	Remove / import and configuration	3
2.5	Known problems and limitations	3
2.6	Getting help / further information	3
2.7	How to get the latest information & software?.....	3
	Contacts.....	4

*) DTM500 Bundle Supplement Info is available on the data medium \documentation or latest on www.abb.com/fieldbus.
Enter here in the search field following No. "3KXD801500R3901".

1 Device - Revision Record - What is new?

1.1 Hardware ID: 0008

Released Revision	Released Date	Remarks
01.00.00	July 2019	First release

1.2 Firmware

Released Revision	Released Date	Remarks
08.01.01	June 2019	First release

1.3 Device (latest SW compatibility status)

Released Revision	Released Date	Remarks
01	June 2019	First release

1.4 Supported devices

Field Indicator JDF300 FF with HW Version 01.00.00, SW Version 08.01.01 and Device revision 01 or higher.

1.5 Cyber Security info

1.5.1 ABB recommendation

A virus scanner shall be used on all PCs/Notebooks. McAfee VirusScan® Enterprise has been tested and qualified for this purpose.

1.6 Licensing

The "General terms of license for computer soft-ware utilization" are valid, which can be found by searching on abb.com

2 EDD/CF

JDF300 Field Indicator FOUNDATION Fieldbus-H1

2.1 EDD/CF Version record - What is new?

Released Version	Released Date	Remarks
010101	June 2019	First release

2.2 Supported Languages

The device DTM supports English

2.3 Requirements

2.3.1 EDD Host application / compatibility

For all certified FOUNDATION Fieldbus Frame applications by Fieldbus Foundation.

2.4 Remove / import and configuration

Start your EDD Host application and follow the instructions.

2.5 Known problems and limitations

None known

2.6 Getting help / further information

Help concerning the integration of the driver in the EDD HOST application can be found in the respective documentation of the frame application.

Use mouse over for field hints and tooltips.

2.7 How to get the latest information & software?

The latest device driver Supplement Info & soft-ware (driver) is available on www.abb.com/measurement

Contacts

—

ABB Limited

Measurement & Analytics

Howard Road, St. Neots
Cambridgeshire, PE19 8EU
UK

Tel: +44 (0) 870 600 6122

Fax: +44 (0)1480 213 339

Email: enquiries.mp.uk@gb.abb.com

ABB S.p.A.

Measurement & Analytics

Via Luigi Vaccani 4

22016 Tremezzina (CO)

Italy

Tel: +39 0344 58111

ABB Inc.

Measurement & Analytics

125 E. County Line Road

Warminster PA 18974

USA

Tel: +1 215 674 6000

Fax: +1 215 674 7183

<https://abb.com/measurement>

We reserve the right to make technical changes or modify the contents of this document without prior notice.

With regard to purchase orders, the agreed particulars shall prevail.

ABB does not accept any responsibility whatsoever for potential errors or possible lack of information in this document.

We reserve all rights in this document and in the subject matter and illustrations contained therein. Any reproduction, disclosure to third parties or utilization of its contents – in whole or in parts – is forbidden without prior written consent of ABB.

Copyright© 2019 ABB

All rights reserved