

产品认证证书

II型自愿认证

证书编号: CQC2013010304630223

发证日期: 2021 年 07 月 01 日

有效期至: 2023 年 07 月 18 日

委托人名称	ABB Electrification Sweden AB, Motor Starting & Safety
及注册地址	Motorgrand 20, 72161 Vasteras, Sweden
制造商名称	ABB Electrification Sweden AB, Motor Starting & Safety
及注册地址	Motorgrand 20, 72161 Vasteras, Sweden
生产企业名称	ABB Industrial Solutions (Klodzko) Sp. z o.o.
及生产地址	ul. Pilsudskiego 5, 57-300 Klodzko, Poland
产品名称和系列、 规格、型号	辅助触头模块 P9B10VN, P9B01VN, P9B10BN, P9B01BN, P9B10VA, P9B01VR, P9B11VN, P9B20VN, P9B02VN, P9B10FN, P9B01FN; U _i : 690V; U _{imp} : 4kV; AC-15: U _e /I _e : 60V/10A, 110V/6A, 220V/3A, 380V/2A, 500V/1.5A, 600V/1.2A; DC-13: U _e /I _e : 24V/2.5A, 48V/1.4A, 60V/1A, 110V/0.55A, 220V/0.27A, 300V/0.2A; I _{th} : 10A; 外壳防 护等级: IP66 (壳体), IP20 (端子); 型号解释见附件
产品标准和技术要求	GB/T 14048.5-2017
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020 年 08 月 28 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

陈昕

签发

谢肇煦

中国质量认证中心



产品认证证书

II型自愿认证

附 录

证书编号: CQC2013010304630223

第 1 页 共 1 页

纸 号:

型号解释:

P9	B	01	V	N
I	II	III	IV	V

I	Series Identification: 系列号 P9 – Series P9: P9 系列
II	Form: 形式 B – Contact Block 触头模块
III	Contacts: 触头 10 – 1 Normally open. 1 常开 01 – 1 Normally closed. 1 常闭 11 – 1 Normally open and 1 Normally closed. 1 常开+1 常闭 02 – 2 Normally closed. 2 常闭 20 – 2 Normally open. 2 常开
IV	Mounting: 安装类型 V – To panel 面板安装 B – Base mounting (only III = 01 and III = 10) 底版安装 F – Fast-on 快速安装
V	Type: 类型 N – Normal. 常规 A – Early close.(only P9B10VA) 提前闭合 R – Late open.(only P9B01VR) 延时断开

注: 此附录与证书同时使用时有效。



中国质量认证中心