












Guide de choix systèmes de gestion adressable

Enveloppes															
	BAES	LSC	BAES	BAES	LSC	BAES	LSC	BAES	BAES	LSC	BAES	LSC			
Technologie															
Adressable SATI	●	○	●	●	○	●	●	○	●	○	●	○	●	○	
Sources lumineuses															
LED	●	○	●	-	-	●	●	○	●	-	●	○	●	-	-
Cathode Froide	-	-	-	●	○	-	-	-	-	-	-	-	○	-	-
Fluorescent	-	-	-	-	-	-	-	●	○	-	-	-	●	○	-
Incandescent	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Fonctions															
Evacuation	●	○	●	●	○	●	●	○	●	-	●	○	●	●	-
Ambiance	●	○	-	-	-	-	●	○	●	○	●	○	●	○	○
Locaux à sommeil	-	-	-	-	-	●	●	-	●	-	●	-	-	-	-
Habitation	-	-	-	-	○	●	●	○	●	-	●	○	-	○	-
DBR	-	-	-	-	-	-	●	-	-	-	●	○	-	-	-
DL	-	-	-	-	-	-	●	-	-	-	-	-	-	-	-
Indices de Protection															
Non-Etanche	-	IP 20 / IK 04	IP 42 / IK 07	IP 42 / IK 07	IP 42 / IK 07	IP 42 / IK 07	IP 42 / IK 07	IP 42 / IK 07 (sans vis) IP 42 / IK 10 (avec vis)	-	-	-	-	-	-	
Etanche	IP 65 / IK 08	-	-	IP 65 / IK 10	IP 65 / IK 10	IP 66 / IK 10	IP 65 / IK 10	IP 55 / IK 08	IP 68 / IK 10	IP 66 / IK 08	IP 66 / IK 10	IP 66 / IK 10	IP 66 / IK 10		
Pages	15 - 16	21	25 - 26	29 - 30	35 - 39	43 - 45	49 - 52	63	69 - 70	67	61				

● BAES = Bloc Autonome d'Eclairage de Sécurité ○ LSC = Luminaire de Source Centrale