

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Circuit breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the factory

ABB Bulgaria EOOD - Rakovski Branch -  
Rakovski Industrial zone, 14, Industrial Road 1,  
4142 RAKOVSKI  
BULGARIA*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

 Additional Information on page 2  
AC 230/400 V; In = 0,2 A ... 63 A;  
Characteristic B, C, D, K, Z;  
Icu = 15 kA; Ics = 7,5 / 11,25 kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series SU200ML

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007  
IEC 60947-1:2007/AMD1:2010  
IEC 60947-1:2007/AMD2:2014  
IEC 60947-2:2016  
IEC 60947-2:2016/AMD1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

252680-TL3-1

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2020-08-011

Signature:



A. Fabian