



中国国家强制性产品认证证书

证书编号：2013010304653298

委托人名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产者（制造商）名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产企业名称、地址

ABB 新会低压开关有限公司

广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

接触器式继电器

NX: Ui:690V; Uimp:6kV; Ith:16A; AC-15:Ue/Ie:24-127V/6A, 230-240V/4A, 400-415V/3A, 500-690V/2A, DC-13:Ue/Ie:24V/6A, 48V/2.8A, 72V/1A, 125V/0.55A, 250V/0.3A; IP20(线圈端子),IP10(主回路端子); 型号解释见附件

产品标准和技术要求

GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，特发此证。

发证日期：2018 年 10 月 22 日 有效期至：2023 年 10 月 22 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2013 年 11 月 04 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2013010304653298

NAME AND ADDRESS OF THE APPLICANT

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

NAME AND ADDRESS OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co., Ltd.

Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Contactor relay

NX: Ui:690V; Uimp:6kV; Ith:16A; AC-15:Ue/Ie:24-127V/6A, 230-240V/4A, 400-415V/3A, 500-690V/2A, DC-13:Ue/Ie:24V/6A, 48V/2.8A, 72V/1A, 125V/0.55A, 250V/0.3A; IP20(Coil terminal),IP10(Main circuit terminal)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Oct.22,2018

Valid until: Oct.22,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Nov.04,2013

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录


第 1 页 共 1 页

证书编号: 2013010304653298

纸 号: 2086170

型号解释:

NX 22 E-80



控制线圈型号代码 type of control circuit 见表一 table1

EN50011 标准定义的接触器继电器的特征符号
Characteristic symbol of contactor relay according to
EN50011 standard define

NC contact series (2, 1, 0)

常闭触点对数 (2, 1, 0)

NO contact series (2, 3, 4)

常开触点对数 (2, 3, 4)

系列名称: NX 系列接触器式继电器 Series product name:
NX Contactor Relay

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心