

Voltage monitoring relays CM-EFS.2

For single-phase AC/DC voltages

The CM-EFS.2 is an electronic voltage monitoring relay that provides reliable monitoring of voltages as well as detection of phase loss.

All devices are available with two different terminal versions. You can choose between the proven screw connection technology (double-chamber cage connecting terminals) and the completely tool-free Easy Connect Technology (push-in terminals).

Characteristics

- Monitoring of DC and AC voltages (3-600 V)
- TRMS measuring principle
- One device includes 4 measuring ranges
- Over- and undervoltage monitoring
- ON- or OFF-delay configurable
- Latching function configurable
- Threshold values for >U and <U adjustable
- Fixed hysteresis (5 %)
- Precise adjustment by front-face operating controls
- Screw connection technology or Easy Connect Technology available
- Housing material for highest fire protection classification UL 94 V-0
- Tool-free mounting on DIN rail as well as demounting
- Tripping delay T_V adjustable (0 s; 0.1-30 s)
- 1x2 c/o (SPDT) contacts (common signal) or 2x1 c/o (SPDT) contact (separate signals for >U and <U) configurable
- 22.5 mm (0.89 in) width
- 3 LEDs for status indication

Order data

Voltage monitoring relays

Type	Rated control supply voltage	Connection technology	Measuring ranges	Order code
CM-EFS.2P	24-240 V AC/DC	Push-in terminals	3-30 V, 6-60 V, 30-300 V, 60-600 V	1SVR740750R0400
CM-EFS.2S	24-240 V AC/DC	Screw type terminals	3-30 V, 6-60 V, 30-300 V, 60-600 V	1SVR730750R0400

Accessories

Type	Description	Order code
ADP.01	Adapter for screw mounting	1SVR430029R0100
MAR.12	Marker label for devices with DIP switches	1SVR730006R0000
COV.11	Sealable transparent cover	1SVR730005R0100



2CDC 251 059 V0011

Approvals

	UL 508, CAN/CSA C22.2 No.14
	GL
	EAC
	CCC
	RMRS

Marks

	CE
	RCM


Connection technology

Maintenance free Easy Connect Technology with push-in terminals

Type designation CM-xxS.yyP


Approved screw connection technology with double-chamber cage connecting terminals

Type designation CM-xxS.yyS



Push-in terminals

- Tool-free connection of rigid and flexible wires with wire end ferrule
- Easy connection of flexible wires without wire end ferrule by opening the terminals
- No retightening necessary
- One operation lever for opening both connecting terminals
- For triggering the lever and disconnecting of wires you can use the same tool (Screwdriver according to DIN ISO 2380-1 Form A 0.8 x 4 mm (0.0315 x 0.157 in), DIN ISO 8764-1 PZ1 ø 4.5 mm (0.177 in))
- Constant spring force on terminal point independent of the applied wire type, wire size or ambient conditions (e. g. vibrations or temperature changes)
- Opening for testing the electrical contacting
- Gas-tight




Double-chamber cage connecting terminals

- Terminal spaces for different wire sizes
- One screw for opening and closing of both cages
- Pozidrive screws for pan- or crosshead screwdrivers according to DIN ISO 2380-1 Form A 0.8 x 4 mm (0.0315 x 0.157 in), DIN ISO 8764-1 PZ1 ø 4.5 mm (0.177 in)

Both the Easy Connect Technology with push-in terminals and screw connection technology with double-chamber cage connecting terminals have the same connection geometry as well as terminal position.

Functions

Operating controls



1 Adjustment of the threshold value $>U$ for overvoltage

2 Adjustment of the threshold value $<U$ for undervoltage

3 Indication of operational states

U/T: green LED – control supply voltage/timing

R: yellow LED – relay status

U: red LED – over- / undervoltage

4 Adjustment of the measuring range

5 Adjustment of the tripping delay T_v

6 DIP switches (see DIP switch functions)

Application

The voltage monitoring relays CM-EFS.2 are designed for use in single-phase AC and/or DC systems for the simultaneous monitoring of over- and undervoltages as well as detection of phase loss. Depending on the configuration, one c/o (SPDT) contact each or both c/o (SPDT) contacts in parallel can be used for the over- and undervoltage monitoring. The devices operate over an universal range of supply voltages, provide an adjustable tripping delay and work according to the open- or closed-circuit principle.

Operating mode

The CM-EFS.2 have 2 c/o (SPDT) contacts and include 4 measuring ranges: 3-30 V, 6-60 V, 30-300 V and 60-600 V.

The units are adjusted with front-face operating controls. The selection of: ON-delay or OFF-delay , open- or closed-circuit principle , latching function ON or OFF and 2x1 c/o or 1x2 c/o (SPDT) contacts is made with DIP switches. Potentiometers, with direct reading scale, allow the adjustment of the threshold value_{max} ($>U$) for overvoltage, the threshold value_{min} ($<U$) for undervoltage and the tripping delay T_v . The tripping delay T_v is adjustable over a range of instantaneous to a 30 s delay. The hysteresis is fixed at 5 %. Timing is displayed by a flashing green LED labelled U/T.

Function diagrams

Voltage window monitoring 1x2 c/o (SPDT) contacts ON-delayed without latching

Open-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. The control supply voltage applied to terminals A1-A2 is displayed by the glowing green LED.

If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the tripping delay T_V starts and the red LED glows (overvoltage), or flashes (undervoltage) respectively.

Timing of T_V is displayed by the flashing green LED.

When T_V is complete and the measured value still exceeds the threshold value_{max} minus the fixed hysteresis (5 %) or is still below the threshold value_{min} plus the fixed hysteresis (5 %), the output relays energize and the yellow LED (relay energized) glows.

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the output relays de-energize and the red and yellow LEDs turn off.

If control supply voltage is interrupted, the green LED turns off.

Closed-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. When control supply voltage is applied to terminals A1-A2, the output relays energize and the green and yellow LED (relays energized) glow.


If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the tripping delay T_V starts and the red LED glows (overvoltage), or flashes (undervoltage) respectively.

Timing of T_V is displayed by the flashing green LED.

When T_V is complete and the measured value still exceeds the threshold value_{max} minus the fixed hysteresis (5 %) or is still below the threshold value_{min} plus the fixed hysteresis (5 %), the output relays de-energize and the yellow LED (relays energized) turns off.

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the output relays re-energize, the yellow LED glows and the red LED turns off.

If control supply voltage is interrupted, the output relays de-energize and the yellow and green LEDs turn off.



Voltage window monitoring 1x2 c/o (SPDT) contacts OFF-delayed without latching

Open-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. The control supply voltage applied to terminals A1-A2 is displayed by the glowing green LED.

If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the output relays energize, the yellow LED (relays energized) glows and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the tripping delay T_V starts and the red LED turns off.

Timing of T_V is displayed by the flashing  green LED. When T_V is complete, the output relays de-energize and the yellow LED (relay energized) turns off.

If control supply voltage is interrupted, the green LED turns off.

Closed-circuit principle


The voltage to be monitored (measured value) is applied to terminals B-C. When control supply voltage is applied to terminals A1-A2, the output relays energize and the green and yellow LED (relays energized) glow.

If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the output relays de-energize, the yellow LED turns off and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the tripping delay T_V starts and the red LED turns off.

Timing of T_V is displayed by the flashing  green LED. When T_V is complete, the output relays energize and the yellow LED (relay energized) glows.

If control supply voltage is interrupted, the output relays de-energize and the yellow and green LEDs turn off.



Voltage window monitoring 1x2 c/o (SPDT) contacts ON-delayed with latching

Open-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. The control supply voltage applied to terminals A1-A2 is displayed by the glowing green LED.

If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the tripping delay T_V starts and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

Timing of T_V is displayed by the flashing  green LED.

When T_V is complete and the measured value still exceeds the threshold value_{max} minus the fixed hysteresis (5 %) or is still below the threshold value_{min} plus the fixed hysteresis (5 %), the output relays energize and the yellow LED (relay energized) flashes .

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the red LED turns off. The output relays remain energized (latching function).

If control supply voltage is interrupted (reset), the output relays de-energize and the yellow and green LEDs turn off.

Closed-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. When control supply voltage is applied to terminals A1-A2, the output relays energize and the green and yellow LED (relays energized) glow.


If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the tripping delay T_V starts and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

Timing of T_V is displayed by the flashing  green LED.

When T_V is complete and the measured value still exceeds the threshold value_{max} minus the fixed hysteresis (5 %) or is still below the threshold value_{min} plus the fixed hysteresis (5 %), the output relays de-energize and the yellow LED (relays energized) flashes .

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the red LED turns off. The output relays remain de-energized (latching function).

If control supply voltage is interrupted (reset), the yellow and green LEDs turn off. The output relays energize again when control supply voltage is re-applied.



Voltage window monitoring 1x2 c/o (SPDT) contacts OFF-delayed with latching

Open-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. The control supply voltage applied to terminals A1-A2 is displayed by the glowing green LED.

If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the output relays energize, the yellow LED (relays energized) flashes  and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the red LED turns off. The output relays remain energized (latching function).

If control supply voltage is interrupted (reset), the output relays de-energize and the yellow and green LEDs turn off.


Closed-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. When control supply voltage is applied to terminals A1-A2, the output relays energize and the green and yellow LED (relays energized) glow.

If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the output relays de-energize, the yellow LED (relays energized) flashes  and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the red LED turns off. The output relays remain de-energized (latching function).

If control supply voltage is interrupted (reset), the yellow and green LEDs turn off. The output relays energize again when control supply voltage is re-applied.



Voltage window monitoring 2x1 c/o (SPDT) contact  ON-delayed  without latching 

Open-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. The control supply voltage applied to terminals A1-A2 is displayed by the glowing green LED.

If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the tripping delay T_V starts and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

Timing of T_y is displayed by the flashing  green LED.

When T_v is complete and the measured value still exceeds the threshold value_{max} minus the fixed hysteresis (5 %) or is still below the threshold value_{min} plus the fixed hysteresis (5 %), the output relay 11₁₅-12₁₆/14₁₈ (>U), or 21₂₅-22₂₆/24₂₈ (<U) respectively, energizes and the yellow LED (relay energized) glows.

If the measured value decreases below the threshold value v_{\max} minus the fixed hysteresis (5 %) or exceeds the threshold value v_{\min} plus the fixed hysteresis (5 %), the output relay $11_{15}-12_{16}/14_{18} (>U)$, or $21_{25}-22_{26}/24_{28} (<U)$ respectively, de-energizes and the red and yellow LEDs turn off.

If control supply voltage is interrupted, the green LED turns off.

Closed-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. When control supply voltage is applied to terminals A1-A2, the output relays energize and the green and yellow LED (relays energized) glow.


If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the tripping delay T_V starts and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

Timing of T_V is displayed by the flashing green LED.

When T_V is complete and the measured value still exceeds the threshold value_{max} minus the fixed hysteresis (5 %) or is still below the threshold value_{min} plus the fixed hysteresis (5 %), the output relay 11₁₅-12₁₆/14₁₈ (>U), or 21₂₅-22₂₆/24₂₈ (<U) respectively, de-energizes and the yellow LED (relays energized) turns off.

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the output relay 11₁₅-12₁₆/14₁₈ (>U), or 21₂₅-22₂₆/24₂₈ (<U) respectively, re-energizes, the yellow LED glows and the red LED turns off.

If control supply voltage is interrupted, the output relays de-energize and the yellow and green LEDs turn off.



Voltage window monitoring 2x1 c/o (SPDT) contact 2x1 c/o OFF-delayed ■ without latching ☒

Open-circuit principle 

The voltage to be monitored (measured value) is applied to terminals B-C. The control supply voltage applied to terminals A1-A2 is displayed by the glowing green LED.

If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, energizes, the yellow LED (relays energized) glows and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the tripping delay T_V starts and the red LED turns off.

Timing of T_V is displayed by the flashing  green LED. When T_V is complete, the output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, de-energizes and the yellow LED (relay energized) turns off.

If control supply voltage is interrupted, the green LED turns off.

Closed-circuit principle 


The voltage to be monitored (measured value) is applied to terminals B-C. When control supply voltage is applied to terminals A1-A2, the output relays energize and the green and yellow LED (relays energized) glow.

If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, de-energizes, the yellow LED turns off and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the tripping delay T_V starts and the red LED turns off.

Timing of T_V is displayed by the flashing  green LED. When T_V is complete, the output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, energizes and the yellow LED (relay energized) glows.

If control supply voltage is interrupted, the output relays de-energize and the yellow and green LEDs turn off.



Voltage window monitoring 2x1 c/o (SPDT) contact ON-delayed with latching

Open-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. The control supply voltage applied to terminals A1-A2 is displayed by the glowing green LED.

If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the tripping delay T_V starts and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

Timing of T_V is displayed by the flashing  green LED.

When T_V is complete and the measured value still exceeds the threshold value_{max} minus the fixed hysteresis (5 %) or is still below the threshold value_{min} plus the fixed hysteresis (5 %), the output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, energizes and the yellow LED (relay energized) flashes .

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the red LED turns off. The output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, remains energized (latching function).

If control supply voltage is interrupted (reset), the output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, de-energizes and the yellow and green LEDs turn off.

Closed-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. When control supply voltage is applied to terminals A1-A2, the output relays energize and the green and yellow LED (relays energized) glow.


If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the tripping delay T_V starts and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

Timing of T_V is displayed by the flashing  green LED.

When T_V is complete and the measured value still exceeds the threshold value_{max} minus the fixed hysteresis (5 %) or is still below the threshold value_{min} plus the fixed hysteresis (5 %), the output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, de-energizes and the yellow LED (relays energized) flashes .

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the red LED turns off. The output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, remains de-energized (latching function).

If control supply voltage is interrupted (reset), the yellow and green LEDs turn off. The output relays energize again when control supply voltage is re-applied.



Voltage window monitoring 2x1 c/o (SPDT) contact OFF-delayed with latching

Open-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. The control supply voltage applied to terminals A1-A2 is displayed by the glowing green LED.

If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, energizes, the yellow LED (relays energized) flashes  and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the red LED turns off. The output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, remains energized (latching function).

If control supply voltage is interrupted (reset), the output relays de-energize and the yellow and green LEDs turn off.


Closed-circuit principle

The voltage to be monitored (measured value) is applied to terminals B-C. When control supply voltage is applied to terminals A1-A2, the output relays energize and the green and yellow LED (relays energized) glow.

If the measured value exceeds the threshold value_{max} ($>U$) or drops below the threshold value_{min} ($<U$), the output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, de-energizes, the yellow LED (relays energized) flashes  and the red LED glows (overvoltage), or flashes  (undervoltage) respectively.

If the measured value decreases below the threshold value_{max} minus the fixed hysteresis (5 %) or exceeds the threshold value_{min} plus the fixed hysteresis (5 %), the red LED turns off. The output relay 11₁₅-12₁₆/14₁₈ ($>U$), or 21₂₅-22₂₆/24₂₈ ($<U$) respectively, remains de-energized (latching function).

If control supply voltage is interrupted (reset), the yellow and green LEDs turn off. The output relays energize again when control supply voltage is re-applied.



Electrical connection

A1	11 ₁₅	21 ₂₅
B		
B	11 ₁₅	21 ₂₅
C		
A1	A2	12 ₁₆ 14 ₁₈ 22 ₂₆ 24 ₂₈
14 ₁₈	12 ₁₆	C
24 ₂₈	22 ₂₆	A2

2CDC 252 207 F0005

A1-A2

Rated control supply voltage

B-C

Measuring ranges: 3-30 V, 6-60 V, 30-300 V, 60-600 V

11₁₅-12₁₆/14₁₈
21₂₅-22₂₆/24₂₈

Output contacts - open- or closed-circuit principle

Connection diagram

DIP switches

Position	4	3	2	1
ON ↑	2x1 c/o		closed	
OFF	1x2 c/o	X	open	X

2CDC 252 274 F0005

- 1 ON OFF-delay
 OFF ON-delay
- 2 ON Closed-circuit principle
 OFF Open-circuit principle
- 3 ON Latching function activated
 OFF Latching function not activated
- 4 ON 2x1 c/o (SPDT) contact
 OFF 1x2 c/o (SPDT) contacts

OFF = Default

Technical data

Data at $T_a = 25^\circ\text{C}$ and rated values, unless otherwise indicated

Input circuits

Supply circuit	A1-A2	
Rated control supply voltage U_s	24-240 V AC/DC	
Rated control supply voltage U_s tolerance	-15...+10 %	
Rated frequency	50/60 Hz	
Typical current / power consumption	24 V DC 115 V AC 230 V AC	30 mA / 0.75 W 17 mA / 1.9 VA 11 mA / 2.6 VA
Power failure buffering time		20 ms
Transient overvoltage protection		varistors

Measuring circuit	B-C	
Monitoring function		Over- and undervoltage monitoring
Measuring method		TRMS measuring principle
Measuring inputs	terminal connection measuring range input resistance pulse overload capacity $t < 1 \text{ s}$ continuous capacity	B-C 3-30 V, 6-60 V, 30-300 V, 60-600 V 600 kΩ 800 V 660 V
Threshold value		> U and < U adjustable within the indicated measuring range
Tolerance of the adjusted threshold value		10 % of the range end value
Hysteresis related to the threshold value		5 % fixed
Measuring signal frequency range		DC / 15 Hz - 2 kHz
Rated measuring signal frequency range		DC / 50-60 Hz
Maximum response time	AC DC	80 ms 120 ms
Accuracy within the rated control supply voltage tolerance		$\Delta U \leq 0.5 \%$
Accuracy within the temperature range		$\Delta U \leq 0.06 \% / {}^\circ\text{C}$
Transient overvoltage protection		varistors

Timing circuit		
Time delay T_v		0 s or 0.1-30 s adjustable
Repeat accuracy (constant parameters)		$\pm 0.07 \%$ of full scale
Tolerance of the adjusted time delay		-
Accuracy within the rated control supply voltage tolerance		$\Delta t \leq 0.5 \%$
Accuracy within temperature range		$\Delta t \leq 0.06 \% / {}^\circ\text{C}$

User interface

Indication of operational states		
Control supply voltage	U/T: green LED	: control supply voltage applied
Measured value	U: red LED	: tripping delay T_v active : overvoltage : undervoltage
Relay status	R: yellow LED	: output relay energized, no latching function : output relay energized, active latching function : output relay de-energized, active latching function

Output circuits

Kind of output	11-12/14 21-22/24	relay, 1st c/o (SPDT) contact relay, 2nd c/o (SPDT) contact 1 x 2 c/o (SPDT) contacts (common signal) or 2 x 1 c/o (SPDT) contact (separate signal for >U and <U) configurable
Operating principle		open- or closed-circuit principle configurable (open- circuit principle: output relays energize if the measured value exceeds / falls below the adjusted threshold value, closed-circuit principle: output relays de-energize if measured value exceeds / falls below the adjusted threshold value)
Contact material		AgNi
Rated operational voltage U_e		250 V
Minimum switching voltage / Minimum switching current		24 V / 10 mA
Maximum switching voltage / Maximum switching current		250 V AC / 4 A AC
Rated operational current I_e	AC-12 (resistive) at 230 V AC-15 (inductive) at 230 V DC-12 (resistive) at 24 V DC-13 (inductive) at 24 V	4 A 3 A 4 A 2 A
AC rating (UL 508)	utilization category (Control Circuit Rating Code) max. rated operational voltage max. continuous thermal current at B 300 max. making/breaking apparent power at B 300	B 300 300 V AC 5 A 3600/360 VA
Mechanical lifetime		30 x 10 ⁶ switching cycles
Electrical lifetime	AC-12, 230 V, 4 A	0.1 x 10 ⁶ switching cycles
Maximum fuse rating to achieve short-circuit protection	n/c contact n/o contact	6 A fast-acting 10 A fast-acting

General data

MTBF	on request		
Duty time	100 %		
Dimensions (W x H x D)	product dimensions	22.5 x 85.6 x 103.7 mm (0.89 x 3.37 x 4.08 in)	packaging dimensions
		97 x 109 x 30 mm (3.82 x 4.29 x 1.18 in)	
Weight	Screw connection technology	Easy Connect Technology (Push-in)	
	Net weight	0.157 kg (0.346 lb)	0.146 kg (0.322 lb)
	Gross weight	0.179 kg (0.395 lb)	0.168 kg (0.370 lb)
Mounting	DIN rail (IEC/EN 60715), snap-on mounting without any tool		
Mounting position	any		
Material of housing	UL 94 V-0		
Degree of protection	housing	IP50	terminals
		IP20	

Electrical connection

		Screw connection technology	Easy Connect Technology (Push-in)
Connecting capacity	fine-strand with(out) wire end ferrule	1 x 0.5-2.5 mm ² (1 x 18-14 AWG) 2 x 0.5-1.5 mm ² (2 x 18-16 AWG)	2 x 0.5-1.5 mm ² (2 x 18-16 AWG)
	rigid	1 x 0.5-4 mm ² (1 x 20-12 AWG) 2 x 0.5-2.5 mm ² (2 x 20-14 AWG)	2 x 0.5-1.5 mm ² (2 x 20-16 AWG)
Stripping length		8 mm (0.32 in)	
Tightening torque		0.6 - 0.8 Nm (7.08 lb.in)	-

Environmental data

Ambient temperature ranges	operation	-25...+60 °C (-13...+140 °F)
	storage	-40...+85 °C (-40...+185 °F)
Damp heat, cyclic (IEC/EN 60068-2-30)		55 °C, 6 cycles
Vibration, sinusoidal		Class 2
Shock		Class 2

Isolation data

Rated insulation voltage U _i	supply / measuring circuit / output	600 V
	output 1 / output 2	250 V
Rated impulse withstand voltage U _{imp}	supply / measuring circuit / output	6 kV 1.2/50 µs
	output 1 / output 2	4 kV 1.2/50 µs
Pollution degree		3
Overvoltage category		III

Standards / Directives


Standards	IEC/EN 60947-5-1, IEC/EN 60255-27, EN 50178
Low Voltage Directive	2014/35/EU
EMC Directive	2014/30/EU
RoHS Directive	2011/65/EU

Electromagnetic compatibility


Interference immunity to	IEC/EN 61000-6-2
electrostatic discharge	IEC/EN 61000-4-2 Level 3
radiated, radio-frequency, electromagnetic field	IEC/EN 61000-4-3 Level 3
electrical fast transient / burst	IEC/EN 61000-4-4 Level 3
surge	IEC/EN 61000-4-5 Level 3
conducted disturbances, induced by radio-frequency fields	IEC/EN 61000-4-6 Level 3
Interference emission	IEC/EN 61000-6-3
high-frequency radiated	IEC/CISPR 22, EN 55022 Class B
high-frequency conducted	IEC/CISPR 22, EN 55022 Class B

Technical diagrams


Load limit curves




AC load (resistive)



DC load (resistive)




Derating factor F for inductive AC load



Contact lifetime


Dimensions

in **mm** and inches




Accessories


in **mm** and inches



ADP.01 - Adapter for screw mounting



MAR.12 - Marker label for devices with DIP switches



COV.11 - Sealable transparent cover

Further documentation

Document title	Document type	Document number
Electronic products and relays	Technical catalogue	2CDC 110 004 C02xx
CM-EFS.2	Instruction manual	1SVC 730 570 M0000

You can find the documentation on the internet at www.abb.com/lowvoltage

-> Automation, control and protection -> Electronic relays and controls -> Measuring and monitoring relays.

CAD system files

You can find the CAD files for CAD systems at <http://abb-control-products.partcommunity.com>

-> Low Voltage Products & Systems -> Control Products -> Electronic Relays and Controls.

Contact us

ABB STOTZ-KONTAKT GmbH

P. O. Box 10 16 80
69006 Heidelberg, Germany
Phone: +49 (0) 6221 7 01-0
Fax: +49 (0) 6221 7 01-13 25
E-mail: info.desto@de.abb.com

You can find the address of your local sales organisation on the ABB home page
<http://www.abb.com/contacts>
-> Low Voltage Products and Systems

Note:

We reserve the right to make technical changes or modify the contents of this document without prior notice. With regard to purchase orders, the agreed particulars shall prevail. ABB AG does not accept any responsibility whatsoever for potential errors or possible lack of information in this document.

We reserve all rights in this document and in the subject matter and illustrations contained therein. Any reproduction, disclosure to third parties or utilization of its contents – in whole or in parts – is forbidden without prior written consent of ABB AG.