



Ref. Certif. No.

SE-91008

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Measuring relays and protection equipment

Name and address of the applicant

ABB Oy, Distribution Solutions
Muottitie 2A, FI-65100 Vaasa
FINLAND

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

48-250VDC/100-240VAC
24-60VDC

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

REF615 HBFNAFFCBHC1BQB11G
REF615 HBFGDAAHBFH1BCB21G
REV615 HBVBEBEAABC1BFN11G

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60255-27:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

1707999STO-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 8 June 2018

intertek

Signature:

Bo Berglöf

SW

Additional information (if necessary)

The family of 615 series are:

No.	Relay	Type
1	Line Differential Protection Relay	RED615
2	Feeder Protection Relay	REF615
3	Generator and Interconnection	REG615
4	Motor Protection Relay	REM615
5	Transformer Protection Relay	RET615
6	Voltage Protection Relay	REU615
7	Capacitor Bank Protection Relay	REV615

Date: 8 June 2018

Signature: 