

IEC**IECEE**

Ref. Certif. No.

CN54338

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Automatic transfer switching equipment

Name and address of the applicant

ABB Inc.
305 Gregson Drive Cary, North Carolina 27511, USA

Name and address of the manufacturer

ABB Inc.
1555 Scott street, zip code 38668, Senatobia MS, USA

Name and address of the factory

ABB Inc.
1555 Scott street, zip code 38668, Senatobia MS, USA

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp: 8kV; Ui: 1000V; Ith: 1200A; Ue: AC220/380V; Ie: 800-1200A; Utilization Category: AC-33A; Icm: 50.4kA; Icw: 24kA/0.06s; Iq: 65kA; Class PC; ATSE; 3P,4P; Open stype unit: IP00; Type 1 enclosure: IP20; Type 12 enclosure: IP54; Type 3R enclosure: IP24

Trademark / Brand (if any)

ABB

Customer's Testing Facility (CTF) Stage used

ZGS***SX*92XXXXXXX, ZGD***SX*92XXXXXXX,

ZSS***SX*92XXXXXXX, ZSD***SX*92XXXXXXX,

Model / Type Ref.

ZBS***SX*92XXXXXXX, ZBD***SX*92XXXXXXX, ZTS000B0,
ZTSD00B0, ZTST00B0, ZBTS00B0, ZBTSD0B0, ZBTST0B0;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-6-1:2005 (2nd Edition) + AMD 1:2013 for use in conjunction with IEC 60947-1:2007 (5th Edition) + AMD 1:2010

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-098616

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Aug.02,2021

Signature:

Xie ZhaoXu

CB 0063402