



certification documents ELVIO CARNAGHI  
ABB SPA ABB SACE DIV  
DIN-RAIL  
COMPONENTS AND WIRING ACCESSORIES  
VIALE DELL'INDUSTRIA 18  
20010 VITTUONE MI ITALY

Date: 2018/03/21  
Subscriber: 100117278  
PartySite: 536068  
File No: E244046  
Project No: 18SR4851838  
PD No: 18M10510  
Type: R  
PO Number:

Subject: **Procedure And/Or Report Material**

The following material resulting from the investigation under the above numbers is enclosed.

**Issue**

<u>Date</u>	<u>Vol</u>	<u>Sec</u>	<u>Pages</u>	<u>Revised Date</u>
2004/10/29	1	1	Cert of Compliance	

Please file revised pages and illustrations in place of material of like identity. New material should be filed in its proper numerical order.

NOTE: Follow-Up Service Procedure revisions DO NOT include Cover Pages, Test Records and Conclusion Pages. Report revisions DO NOT include Authorization Pages, Indices, Section General Pages and Appendixes.

Please review this material and report any inaccuracies to FRANCESC SCALVINI (EXT. 47581)

This material is provided on behalf of UL LLC (UL) or any authorized licensee of UL.

MEL File

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180321-E244046  
**Report Reference** E244046-20041029  
**Issue Date** 2018-MARCH-21

**Issued to:** ABB SPA ABB SACE DIV DIN-RAIL COMPONENTS AND WIRING ACCESSORIES  
VIALE DELL'INDUSTRIA 18  
20010 VITTUONE MI ITALY

**This is to certify that representative samples of**

**COMPONENT - GROUND-FAULT SENSING AND RELAYING EQUIPMENT**


Component Ground Fault Sensing and Relaying Equipment Series F200. Cat. Nos. F202 and F204 followed by A or AC with or without the letter S followed by 16, 25, 40, 63, 80 or 100 followed by 0.01, 0.03, 0.1, 0.3, 0.5 or 1. May be followed by the letters AP-R


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1053, the Standard for Ground-Fault Sensing and Relaying Equipment  
CSA C22.2 NO. 144-06, Ground Fault Circuit Interrupters

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: , may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180321-E244046  
**Report Reference** E244046-20041029  
**Issue Date** 2018-MARCH-21

Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. The final acceptance of the component is dependent upon its installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

