

IEC 61850 Certificate Level A¹

Page 1/2

Issued to:
ABB Oy
Distribution Automation
Muottitie 2 A
FI-65101 Vaasa
Finland

No. 30920335-Consulting 09-1363

For the product:
630 Series
Software version 1.0.RC16
Hardware version
SBFNABACBBBZANNAXA

Issued by:



The product has not shown to be non-conforming to:

IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in 630 series version 1.0", "Model Implementation Conformance Statement for the IEC 61850 interface in 630 series version 1.0", "630 version 1.0 – IEC 61850 TICS (Tissue Implementation Extra Information)" and product's extra information for testing: "630 version 1.0 – IEC 61850 PIXIT (Protocol Implementation eXtra Information)".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v2.2):

- 1 Basic Exchange (18/24)
- 2 Data Sets (3/6)
- 3 Substitution (4/4)
- 4 Setting Group Selection (2/3)
- 5 Unbuffered Reporting (12/18)
- 6 Buffered Reporting (15/20)

- 9a GOOSE Publish (6/12)
- 9b GOOSE Subscribe (9/10)
- 12a Direct Control (4/11)
- 12d Enhanced SBO Control (10/19)
- 13 Time Synchronization (3/4)
- 14 File Transfer (5/7)

This Certificate includes a summary of the test results as carried out at KEMA in The Neterlands with UniCAsim 61850 version 3.19.02 with test suite 3.19.00 and UniCA 61850 analyzer 4.18.01. The test is based on the UCA International Users Group Device Test Procedures version 2.2. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30920335-Consulting 09-1362 will prevail.

The test has been carried out on one single specimen of the products as referred above and submitted to KEMA by ABB Oy. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, July 2, 2009

W. Strabbing

Manager Intelligent Networks and Communication

S.J.T. Mulder Senior Test Engineer

Sellior rest Engineer

Sylvantation

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.2

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5, Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN3
2: Data Sets	Dset1, Dset10a, DsetN1ae	
3: Substitution	Sub1, Sub2, Sub3, SubN1	
4: Setting Group Selection	Sg1, SgN1a	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, Rp10 RpN1, RpN2, RpN3, RpN4	Rp5, Rp8
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br10
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1, GopN1
9b: GOOSE subscribe	Gos1a, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	
12a: Direct control	CltN3, CtlN8, DOns1, DOns3	
12d: Enhanced SBO control	Ctl3, CltN1, CltN2, CltN3, CltN4, CtlN9 SBOes1, SBOes2, SBOes3	Ctl2
13: Time sync	Tm1, Tm2, TmN1	
14: File transfer	Ft1, Ft2ab, FtN1ab	Ft2c, FtN1c