

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Circuit-breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the factory

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY*Note: When more than one factory, please report on page 2* Additional Information on page 2

Ratings and principal characteristics

AC 240/415 V; Icn: 25 kA (type "B" (6 - 25) A; type "C,  
D" (0,5 - 25) A)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Serie / Series S30.P

Additional information (if necessary may also  
be reported on page 2)Icn: 20 kA (type "B, C, D" 32 A; 40 A)  
Icn: 15 kA (type " B, C, D" 50 A; 63 A) Additional Information on page 2A sample of the product was tested and found  
to be in conformity withIEC 60898-1:2015  
IEC 60898-1:2015/AMD1:2019As shown in the Test Report Ref. No. which  
forms part of this Certificate

273609-TL3-000 to 273609-TL3-077

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2021-09-21

Signature:



J. Richter