



中国国家强制性产品认证证书

证书编号: 2024010304659821

认证委托人名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产者名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称及地址

ABB Bulgaria EOOD
1, Varna Str., 2850 Petrich, Bulgaria

产品名称和系列、型号、规格

热过载继电器

TF140DU; Ui:690V;Ue:690V;Ie:66-90,80-110,100-135,110-142A;脱扣级别:10A;极数:3P;IP20; 配用的辅助触头:(本体)Ith:6A(NO),10A(NC);AC-15:NO:Ue/Ie:240V/1.5A,440V/1A,500V/1A;AC-15:NC:Ue/Ie:240V/3A,440V/1A,500V/1A;
DC-13:NO:Ue/Ie:24V/1.25A,125V/0.25A,250V/0.04A;DC-13:NC:Ue/Ie:24V/1.25A,125V/0.25A,250V/0.12A;1NO1NC; 型号解释详见附页

产品标准和技术要求

GB/T 14048.4-2020

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》(CNCA-C03-02:2024)的要求,特发此证。

发证日期: 2024年07月18日 有效期至: 2029年07月17日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,也可在认监委网站(www.cnca.gov.cn)查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2024010304659821

证书附页：第 1 页 共 1 页

型号解释：

TF 140 D U - 142 - V1000
1 2 3 4 5 6

1. Series Name for Thermal Overload Relay for AF contactor series
2. Frame size 140
3. phase failure protection
4. Reset manual or automatic
5. Upper setting range
6. Blank: Standard version
-V1000: Optional to indicate the ATEX version

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010304659821

NAME AND ADDRESS OF THE APPLICANT

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND LOCATION OF THE FACTORY

ABB Bulgaria EOOD
1, Varna Str., 2850 Petrich, Bulgaria

PRODUCT NAME,MODEL AND SPECIFICATION

Thermal Overload Relays

TF140DU; Ui:690V;Ue:690V;Ie:66-90,80-110,100-135,110-142A;Trip Class:10A;Poles:3P;IP20; Attached Auxiliary
Contacts:Ith:6A(NO),10A(NC);AC-15:NO:Ue/Ie:240V/1.5A,440V/1A,500V/1A;AC-15:NC:Ue/Ie:240V/3A,440V/1A,500
V/1A;

DC-13:NO:Ue/Ie:24V/1.25A,125V/0.25A,250V/0.04A;DC-13:NC:Ue/Ie:24V/1.25A,125V/0.25A,250V/0.12A;1NO1NC

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.4-2020

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.18,2024

Valid until: Jul.17,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION


本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010304659821

Appendix: Page 1 of 1

TF 140 D U - 142 - V1000
1 2 3 4 5 6

1. Series Name for Thermal Overload Relay for AF contactor series
2. Frame size 140
3. phase failure protection
4. Reset manual or automatic
5. Upper setting range
6. Blank: Standard version
-V1000: Optional to indicate the ATEX version



This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.