



Ref. Certif. No.

CN49527

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Switch-disconnectors

Name and address of the applicant

ABB S.P.A. - ABB SACE Division  
Via Pescaria 5, 24123 Bergamo Italy

Name and address of the manufacturer

ABB S.P.A. - ABB SACE Division  
Via Pescaria 5, 24123 Bergamo Italy

Name and address of the factory

ABB S.P.A. - ABB SACE Division  
Via Enrico Fermi 14, IT-03100 Frosinone Italy

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:12kV;Ui: 1000V;Ith: 1600A Ue: AC440V,  
AC690V;Ie:630A,800A,1000A,1250A,1600A(E1.2B/MS);  
250A,630A,800A,1000A,1250A,1600A  
(E1.2N/MS);Icw:42kA/1s((E1.2B/MS),50kA/1s(E1.2N/MS);Icm  
(peak): 88kA((E1.2B/MS),105 kA(E1.2N/MS); Utilization  
category:AC-23A;Poles:3P,4P;50/60Hz

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

E1.2B/MS,E1.2N/MS;

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007 (5th Edition) + AMD1:2010 + AMD2:2014;IEC  
60947-3:2008(3rd Edition) + AMD 1:2012 + AMD 2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2019CQC-088019

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Mar.03,2020

Signature:

Lu Mei

CB 0054892