


IEC 60034-30-1 standard on efficiency classes for low voltage AC motors




Standard IEC/EN 60034-30-1 on efficiency classes of line operated AC motors was published by the International Electrotechnical Commission (IEC) on March 6, 2014. This IEC standard is concerned with the global harmonization of energy efficiency classes for electric motors. Compared with IEC/EN 60034-30: 2008, it significantly expands the range of products covered with the inclusion of 8-pole motors and introduces IE4 efficiency performance class for electric motors.

What are the efficiency classes defined by IEC/EN 60034-30-1: 2014?

The standard defines four IE (International Efficiency) efficiency classes for single speed electric motors that are rated according to IEC 60034-1 or IEC 60079-0 (explosive atmospheres) and designed for operation on sinusoidal voltage.

Super-Premium efficiency	IE4
Premium efficiency	IE3
High efficiency	IE2
Standard efficiency	IE1

IE efficiency classes for 4 pole motors at 50 Hz



What motors are covered by the standard?

The new standard covers a wider scope of products. The power range has been expanded to cover motors from 120 W to 1000 kW. All technical constructions of electric motors are covered as long as they are rated for direct on-line operation. The coverage of the new standard includes:

- Single speed electric motors (single and three phase), 50 and 60 Hz
- 2, 4, 6 or 8 poles
- Rated output PN from 0.12 kW to 1000 kW
- Rated voltage UN above 50 V up to 1 kV
- Motors, capable of continuous operation at their rated power with a temperature rise within the specified insulation temperature class
- Motors, marked with any ambient temperature within the range of -20 °C to +60 °C
- Motors, marked with an altitude up to 4000 m above sea level

The following motors are excluded from IEC/EN 60034-30-1

- Single-speed motors with 10 or more poles or multi-speed motors
- Motors completely integrated into a machine (for example, pump, fan or compressor) that cannot be tested separately from the machine.
- Brake motors, when the brake can not be dismantled or separately fed.

Table 1

Minimum 50 Hz efficiency values defined in IEC/EN 60034-30-1:2014 (based on test methods specified in IEC 60034-2-1:2014)

Output kW	IE1				IE2				IE3				IE4			
	2 pole	4 pole	6 pole	8 pole	2 pole	4 pole	6 pole	8 pole	2 pole	4 pole	6 pole	8 pole	2 pole	4 pole	6 pole	8 pole
0.12	45.0	50.0	38.3	31.0	53.6	59.1	50.6	39.8	60.8	64.8	57.7	50.7	66.5	69.8	64.9	62.3
0.18	52.8	57.0	45.5	38.0	60.4	64.7	56.6	45.9	65.9	69.9	63.9	58.7	70.8	74.7	70.1	67.2
0.20	54.6	58.5	47.6	39.7	61.9	65.9	58.2	47.4	67.2	71.1	65.4	60.6	71.9	75.8	71.4	68.4
0.25	58.2	61.5	52.1	43.4	64.8	68.5	61.6	50.6	69.7	73.5	68.6	64.1	74.3	77.9	74.1	70.8
0.37	63.9	66.0	59.7	49.7	69.5	72.7	67.6	56.1	73.8	77.3	73.5	69.3	78.1	81.1	78.0	74.3
0.40	64.9	66.8	61.1	50.9	70.4	73.5	68.8	57.2	74.6	78.0	74.4	70.1	78.9	81.7	78.7	74.9
0.55	69.0	70.0	65.8	56.1	74.1	77.1	73.1	61.7	77.8	80.8	77.2	73.0	81.5	83.9	80.9	77.0
075	72.1	72.1	70.0	61.2	77.4	79.6	75.9	66.2	80.7	82.5	78.9	75.0	83.5	85.7	82.7	78.4
1.1	75.0	75.0	72.9	66.5	79.6	81.4	78.1	70.8	82.7	84.1	81.0	77.7	85.2	87.2	84.5	80.8
1.5	77.2	77.2	75.2	70.2	81.3	82.8	79.8	74.1	84.2	85.3	82.5	79.7	86.5	88.2	85.9	82.6
2.2	79.7	79.7	77.7	74.2	83.2	84.3	81.8	77.6	85.9	86.7	84.3	81.9	88.0	89.5	87.4	84.5
3	81.5	81.5	79.7	77.0	84.6	85.5	83.3	80.0	87.1	87.7	85.6	83.5	89.1	90.4	88.6	85.9
4	83.1	83.1	81.4	79.2	85.8	86.6	84.6	81.9	88.1	88.6	86.8	84.8	90.0	91.1	89.5	87.1
5.5	84.7	84.7	83.1	81.4	87.0	87.7	86.0	83.8	89.2	89.6	88.0	86.2	90.9	91.9	90.5	88.3
7.5	86.0	86.0	84.7	83.1	88.1	88.7	87.2	85.3	90.1	90.4	89.1	87.3	91.7	92.6	91.3	89.3
11	87.6	87.6	86.4	85.0	89.4	89.8	88.7	86.9	91.2	91.4	90.3	88.6	92.6	93.3	92.3	90.4
15	88.7	88.7	87.7	86.2	90.3	90.6	89.7	88.0	91.9	92.1	91.2	89.6	93.3	93.9	92.9	91.2
18.5	89.3	89.3	88.6	86.9	90.9	91.2	90.4	88.6	92.4	92.6	91.7	90.1	93.7	94.2	93.4	91.7
22	89.9	89.9	89.2	87.4	91.3	91.6	90.9	89.1	92.7	93.0	92.2	90.6	94.0	94.5	93.7	92.1
30	90.7	90.7	90.2	88.3	92.0	92.3	91.7	89.8	93.3	93.6	92.9	91.3	94.5	94.9	94.2	92.7
37	91.2	91.2	90.8	88.8	92.5	92.7	92.2	90.3	93.7	93.9	93.3	91.8	94.8	95.2	94.5	93.1
45	91.7	91.7	91.4	89.2	92.9	93.1	92.7	90.7	94.0	94.2	93.7	92.2	95.0	95.4	94.8	93.4
55	92.1	92.1	91.9	89.7	93.2	93.5	93.1	91.0	94.3	94.6	94.1	92.5	95.3	95.7	95.1	93.7
75	92.7	92.7	92.6	90.3	93.8	94.0	93.7	91.6	94.7	95.0	94.6	93.1	95.6	96.0	95.4	94.2
90	93.0	93.0	92.9	90.7	94.1	94.2	94.0	91.9	95.0	95.2	94.9	93.4	95.8	96.1	95.6	94.4
110	93.3	93.3	93.3	91.1	94.3	94.5	94.3	92.3	95.2	95.4	95.1	93.7	96.0	96.3	95.8	94.7
132	93.5	93.5	93.5	91.5	94.6	94.7	94.6	92.6	95.4	95.6	95.4	94.0	96.2	96.4	96.0	94.9
160	93.8	93.8	93.8	91.9	94.8	94.9	94.8	93.0	95.6	95.8	95.6	94.3	96.3	96.6	96.2	95.1
200	94.0	94.0	94.0	92.5	95.0	95.1	95.0	93.5	95.8	96.0	95.8	94.6	96.5	96.7	96.3	95.4
250	94.0	94.0	94.0	92.5	95.0	95.1	95.0	93.5	95.8	96.0	95.8	94.6	96.5	96.7	96.5	95.4
315	94.0	94.0	94.0	92.5	95.0	95.1	95.0	93.5	95.8	96.0	95.8	94.6	96.5	96.7	96.6	95.4
355	94.0	94.0	94.0	92.5	95.0	95.1	95.0	93.5	95.8	96.0	95.8	94.6	96.5	96.7	96.6	95.4
400	94.0	94.0	94.0	92.5	95.0	95.1	95.0	93.5	95.8	96.0	95.8	94.6	96.5	96.7	96.6	95.4
450	94.0	94.0	94.0	92.5	95.0	95.1	95.0	93.5	95.8	96.0	95.8	94.6	96.5	96.7	96.6	95.4
500-1000	94.0	94.0	94.0	92.5	95.0	95.1	95.0	93.5	95.8	96.0	95.8	94.6	96.5	96.7	96.6	95.4

What is the classification based on?

The efficiency levels defined in IEC/EN 60034-30-1 are based on the low uncertainty test methods specified in IEC 60034-2-1, which has been updated to edition 2.0, 2014-06. The manufacturer’s documentation must show how the efficiency values are determined. Efficiency values can only be compared if they are based on the same testing method.

What are the threshold levels of the motor efficiency classes?

Table 1 above shows the threshold levels of the motor efficiency classes for 2, 4, 6 and 8 pole motors between 0.12 and 1000 kW.

How is the IE class marked?

The lowest efficiency value and the associated IE-code of the motor are shown on the rating plate.

How is IEC/EN 60034-30-1 compatible with other efficiency standards?

Differences still exist between the various standards. The IEC standard harmonizes the currently different requirements for induction motor efficiency levels around the world, however, making the comparison easier. Work to harmonize standards continues.

Table 2 below shows a rough comparison between IEC/EN 60034-30-1 and main national MEPS schemes world wide. The IEC/EN 60034-30-1 defines only the requirements for the efficiency classes and aims to create a basis for International

consistency. It does not specify which motors must be supplied with which efficiency level. This is left to the respective regional legislation and EU Directive.

Table 2

IEC/EN 60034-30-1	EU MEPS	EISA US EEV Canada	Other, similar local regulations
IE4 Super-Premium efficiency			Japan 2015 Australia/New Zealand 2015 Korea 2015 China 2016
IE3 Premium efficiency	IE3 Premium efficiency	Identical to NEMA Premium efficiency	Canada Mexico Australia New Zealand Brazil
IE2 High efficiency	IE2 High efficiency	Identical to NEMA Energy efficiency/ EPACT	Costa Rica Israel Taiwan
IE1 Standard efficiency		Below standard efficiency	

How does ABB apply the standard?

ABB has calculated motor efficiency values under the efficiency testing standard (IEC 60034-2-1: 2014) according to the indirect method, with additional losses determined from measuring. ABB has a full range of IE2 and IE3 available from stock, and a broad range of IE4 motors

For more information, please contact your local ABB representative or visit:

abb.com/motors-generators

We reserve the right to make technical changes or modify the contents of this document without prior notice. With regard to purchase orders, the agreed particulars shall prevail. ABB Ltd does not accept any responsibility whatsoever for potential errors or possible lack of information in this document.

We reserve all rights in this document and in the subject matter and illustrations contained herein. Any reproduction, disclosure to third parties or utilization of its contents – in whole or in part – is forbidden without prior written consent of ABB Ltd.

Copyright © 2018 ABB, All rights reserved