



NOTIFICATION OF TEST RESULTS

CCA/DE1 34882

<i>Product</i>	Leitungsschutzschalter / Circuit-breaker
<i>Tested by request of</i>	ABB-Stotz-Kontakt GmbH Eppelheimer Straße 82, 69123 Heidelberg GERMANY
<i>Manufactured at (name and place)</i>	ABB-Stotz-Kontakt GmbH Eppelheimer Straße 82, 69123 Heidelberg GERMANY
<i>Preliminary visit carried out by</i>	
<i>Rating and principal characteristics</i>	In: 0,5 A - 63 A; Un: AC 230/400 V; AC 230 V; AC 400 V Number of poles: 1; 2; 3; 4; 1+N; 3+N Instantaneous tripping current: B; C; D; Icn: 10000 A
<i>Trade mark (if any)</i>	ABB
<i>Model/Type Ref.</i>	Series S 200MT
<i>Additional information (if necessary)</i>	
<i>A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)</i>	
EN 60898-1:2019	
<i>as shown in the test reports (reference No.)</i> 295827-TL3-90	

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body which participates directly in the CENELEC Certification Agreement (CCA) of September 11th, 1973 as revised on March 29th, 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA.

The CCA Testing Laboratories are accredited by DAkkS according to DIN EN ISO/IEC 17025:2018.

The accreditation is valid only for the scope listed in the Annex to the accreditation certificates [D-PL-12107-01-00](#) (IPH) and [D-PL-12061-01-01](#) (VDE Institute) as well as in the published list for flexible accreditation available at the [VDE website](#).

Offenbach, 2022-07-15

VDE Prüf- und Zertifizierungsinstitut GmbH


Stamp and signature of the authorized person
T. Baumann

Name, Certification Officer

VDE Prüf- und Zertifizierungsinstitut GmbH
Merianstrasse 28, 63069 Offenbach, Germany

Tel.: +49 69 8306-0
Fax.: +49 69 8306-555
Email: vde-institut@vde.com