



# 中国国家强制性产品认证证书

证书编号：2006010304213057

委托人名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产者（制造商）名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

生产企业名称、地址

ABB France

3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

产品名称和系列、规格、型号

交流接触器

A50-30, A63-30, A75-30, A45-40, A45-22, A50-40, A75-40, A75-22; 详见参数附件

产品标准和技术要求

GB/T14048.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，特发此证。

发证日期：2017年08月21日 有效期至：2022年08月21日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2006年11月29日

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：



## 中国质量认证中心



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

**CERTIFICATE NO.:** 2006010304213057

## **NAME AND ADDRESS OF THE APPLICANT**

ABB France  
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

## **NAME AND ADDRESS OF THE MANUFACTURER**

ABB France  
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

## **NAME AND ADDRESS OF THE FACTORY**

ABB France  
3 Rue Jean Perrin CS 90009 69687 Chassieu Cedex, France

## **PRODUCT NAME, MODEL AND SPECIFICATION**

AC Contactor  
A50-30,A63-30,A75-30,A45-40,A45-22,A50-40,A75-40,A75-22; See the Appendix

## **THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

**Valid from:** Aug.21,2017

**Valid until:** Aug.21,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Nov.29,2006

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



**CHINA QUALITY CERTIFICATION CENTRE**



# 中国国家强制性产品认证证书

附录:

第 1 页 共 5 页

证书编号: 2006010304213057

纸号: 1778894

A50-30,A63-30,A75-30,A45-40,A45-22,A50-40,A75-40,A75-22

Ui:1000V;

A45,A50:Ith:100A;

A63,A75:Ith:125A;

A45-22,A45-40:

AC-1:Ue/Ie:690V/70A;

AC-3,AC-4:Ue/Ie:220-230-240V/40A,380-400/415/440V/37A,500V/33A,690V/25A;

A50-30:

AC-1:Ue/Ie:690V/100A;

AC-3,AC-4:Ue/Ie:220-230-240V/53A,380-400/415V/50A,440/500V/45A,690V/35A;

AC-8a:Ue/Ie:400V/63A;

A50-40:

AC-1:Ue/Ie:690V/100A;

AC-3,AC-4:Ue/Ie:220-230-240V/53A,380-400/415V/50A,440/500V/45A,690V/35A;

A63-30:

AC-1:Ue/Ie:690V/115A;

AC-3,AC-4:Ue/Ie:220-230-240/380-400/415/440V/65A,500V/55A,690V/43A;

AC-8a:Ue/Ie:400V/85A;

A75-30:

AC-1:Ue/Ie:690V/125A;

注: 此附录与证书同时使用时有效。



主任:



## 中国质量认证中心



# 中国国家强制性产品认证证书

附录:

第 2 页 共 5 页

证书编号: 2006010304213057

纸号: 1778894

AC-3,AC-4:Ue/Ie:220-230-240/380-400/415V/75A,440V/70A,500V/65A,690V/46A;

AC-8a:Ue/Ie:400V/95A;

A75-22,A75-40:

AC-1:Ue/Ie:690V/125A;

AC-3,AC-4:Ue/Ie:220-230-240/380-400/415V/75A,440V/70A,500V/65A,690V/46A;

Us:24V 50/60Hz,48V 50/60Hz, 110V 50Hz/110-120V 60Hz,  
220-230V 50Hz/230-240V 60Hz,380-400V 50Hz/400-415V 60Hz,

400-415V 50Hz/415-440V 60Hz;

3P;

IP10

配用辅助触头:

CAL5-11,CA5-40E,CA5-40ERT,CA5-31E, CA5-31ERT,

CA5-22E, CA5-22ERT, CA5-04E, CA5-11/11E, CA5-31M,

CA5-31MRT, CA5-22M, CA5-22MRT, CA5-13M, CA5-04M,

CA5-11/11M, CA5-40U, CA5-31U, CA5-22U, CA5-04U, CA5-40N,

CA5-40NRT, CA5-31N, CA5-31NRT, CA5-22N,

CA5-22NRT, CA5-13N,CA5-04N

Ith:16A

AC-15:Ue/Ie:24-127V/6A, 220-240V/4A, 380-440V/3A, 500-690V/2A;

DC-13:Ue/Ie:24V/6A, 48V/2.8A, 72V/1A, 110-125V/0.55A, 220-250V/0.3A

注: 此附录与证书同时使用时有效。



主任:



## 中国质量认证中心



# 中国国家强制性产品认证证书

附录:

第 3 页 共 5 页

证书编号: 2006010304213057

纸号: 1778894

1NO1NC/1NO leading contact and 1NC lagging contact  
(CA5-11/11E,CA5-11/11M);

1NO1NC(CAL5-11)

1NO3NC(CA5-13M,CA5-13N)

2NO2NC(CA5-22E,CA5-22ERT,CA5-22M,CA5-22MRT,CA5-22U,CA5-22N,CA  
5-22NRT);

3NO1NC(CA5-31E,CA5-31ERT,CA5-31M,CA5-31MRT,CA5-31U,CA5-31N,CA  
5-31NRT)

4NO(CA5-40E,CA5-40ERT,CA5-40U,CA5-40N,CA5-40NRT);

4NC(CA5-04E,CA5-04M,CA5-04U,CA5-04N)

注: 此附录与证书同时使用时有效。



主任:



## 中国质量认证中心



# 中国国家强制性产品认证证书

附录:

第 4 页 共 5 页

证书编号: 2006010304213057

纸号: 1778894

型号的解释:

A	50	30	00	
I	II	III	IV	V

I - Main designation : A

II - Range size

45, 50, 63, 75

III - Main Pole Construction

22 - 2 Normally Opened and 2 Normally Closed main poles.

30 - 3 Normally Opened and 0 Normally Closed main poles.

40 - 4 Normally Opened and 0 Normally Closed main poles.

IV - Auxiliary Pole Construction

00 - No auxiliary pole provided.

11 - One Normally Opened and one Normally Closed auxiliary poles.

V - Coil code

See table 1

List of type

Designation
A45-40-00 + coil voltage
A45-22-00 + coil voltage
A50-30-00 + coil voltage
A50-30-11 + coil voltage
A63-30-00 + coil voltage
A63-30-11 + coil voltage
A75-30-00 + coil voltage

注: 此附录与证书同时使用时有效。



主任:



## 中国质量认证中心



# 中国国家强制性产品认证证书

附录:

第 5 页 共 5 页

证书编号: 2006010304213057

纸号: 1778894

A75-30-11 + coil voltage
A50-40-00 + coil voltage
A75-40-00 + coil voltage
A75-22-00 + coil voltage

注: 此附录与证书同时使用时有效。



主任:



## 中国质量认证中心