



Product Service

# Compliance Document

No. D8 17 07 44254 014

**Holder of Certificate:** ABB Stotz-Kontakt GmbHEppelheimer Str. 82  
69123 Heidelberg  
GERMANY**Product:** Measuring relays and protection equipment  
NS Protection Device  
(System Protection Interface)**Model(s):** CM-UFD.M22M**Parameters:**

Software release:	1.0.x ("x" is from 0 to 9)
Power supply:	24-240Vdc / 110-240Vac; 50 Hz
Voltage monitored lines:	230V/400V; 50 Hz

**Tested according to:** CEI 0-21:2016  
(Reference technical rules for the connection of active and passive users to the LV electrical Utilities)

This Compliance Document confirms the compliance with the above listed standards / test specifications on a voluntary basis. It refers only to the sample submitted to TÜV SÜD Product Service GmbH and does not certify the quality or safety of the serial products. See also notes overleaf.

**Test report no.:** TR-44254-101139-01**Date,** 2017-08-08

( Domenico Pignataro )



Page 1 of 1