

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20120918-E319322  
**Report Reference** E319322-20091127  
**Issue Date** 2012-SEPTEMBER-18

**Issued to:** ABB FRANCE  
ACTIVITE PROTECTION ET CONTROL  
10 RUE AMPERE  
69685 CHASSIEU CEDEX FRANCE


**This is to certify that  
representative samples of** SWITCHES, INDUSTRIAL CONTROL  
See Addendum Page

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 508, Standard for Industrial Control Equipment  
CSA C22.2 No. 14-10, Industrial Control Equipment

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20120918-E319322  
**Report Reference** E319322-20091127  
**Issue Date** 2012-SEPTEMBER-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

General use Switches, Industrial Control, open type; AF09, AF16, AF26, AF38, may be followed by B, may be followed by Z, followed by -22 or -40, followed by -00, followed by 2 digits

General Use rating 4-Poles devices		AF09-22	AF16-22
600 Vac	(A)	25	30
160 Vdc (2 poles in series)		20	20

General Use rating 4-Poles devices		AF09-40	AF16-40
600 Vac	(A)	25	30
240 Vdc (3 poles in series)			

General-Use rating 4 poles devices		AF26-22	AF38-22
600Vac			
160Vdc (2 poles in series)		45A	55A

General-Use rating 4 poles devices		AF26-40	AF38-40
600Vac			
240Vdc (3 poles in series)		45A	55A

## Definite Purpose Controller - Air Conditioning rating

Model	FLA	LRA 480V	LRA 600V
AF09 Pressure Screw Terminals only	20	120	80
AF16 Pressure Screw Terminals only	30	180	120

*William R. Carney*

William R. Carney, Director, North American Certification Programs  
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

