



Product Service

# Compliance Document

No. D8 17 11 44254 017

**Holder of Certificate:** **ABB Stotz-Kontakt GmbH**Eppelheimer Str. 82  
69123 Heidelberg  
GERMANY**Product:** **Protection System  
(System Protection Interface)****Model(s):** **CM-UFD.M31M****Parameters:**

Software release:	1.0.x ("x" is from 0 to 9)
Auxiliary power supply:	24-240Vac,50Hz or 24-240Vdc
Monitoring terminals:	Rated 230V/400Vac,50Hz

**Tested according to:**

BDEW Medium-Voltage Guideline:	2008
FGW TR3:	2016
FGW TR8:	2016

This Compliance Document confirms the compliance with the above listed standards / test specifications on a voluntary basis. It refers only to the sample submitted to TÜV SÜD Product Service GmbH and does not certify the quality or safety of the serial products. See also notes overleaf.

**Test report no.:** TR-44254-14805-04**Date,** 2017-11-24  
( Billy Qiu )

Page 1 of 1