

Certificate of Conformity

No. ESY 044254 0047 Rev. 00

Holder of Certificate: **ABB Stotz-Kontakt GmbH**

Eppelheimer Str. 82
69123 Heidelberg
GERMANY

Product:

Protection System

Model(s):

CM-UFD.M34M

Parameters:

Type:	CM-UFD.M34M
Supply input terminals:	24-240V, DC/50Hz
Measuring inputs:	3ph, 230/400Vac, 50Hz
Other options:	with Modbus RTU
Firmware:	1.0.x

Remarks/CoA (e.g. nomenclature; conditions of acceptability):

Valid until: 2028-03-30

Test Report 713296249-000 summarizes following test reports:

- TR-44254-14805-01 (EMC)
- TR-44254-14805-02 (TR)
- TRFDEW-44254-101139-01 (PD)

Applicable standards:


DEWA:2016 Version 2, March 2016

This Certificate of Conformity confirms the compliance with the above listed standards on a voluntary basis. It refers only to the sample submitted to TÜV SÜD Product Service GmbH and does not certify the quality or safety of the serial products. It was issued according to TÜV SÜD Product Service certification program Photovoltaics and Grid Integration. For details see: www.tuvsud.com/ps-cert

Test report no.:

713296249-000

Date, 2023-04-03



(Kristijan Cizmar)