



Test Report				Date of issue: 11.6.2014							
				Serial No.: 3GF11054639							
				Type: M3GP 355SMB 6 IMB3/IM1001							
				Product Code: 3GGP353220-ADG							
				Protection type: Ex nA IIC T3 Gc							
				Cert. No.: LCIE 12 ATEX 1008X							
				IECEX LCI 07.0001X							
Rating:				V	Hz	kW	r/min	A	cos φ	Duty	
3~Motor Insul.cl.F IP55 Ambient temp. +5°C...+40°C				400	D 50	200	993	359	0,84	S1	
Resistance				Insulation resistance at 62,0 °C				Overload			
Line Ambient: 20,5 °C				5800 MΩ 1000 V				Torque 160 % 15s			
U ₁ - V ₁ 0,00994 Ω											
U ₁ - W ₁ 0,00995 Ω											
V ₁ - W ₁ 0,00994 Ω											
				High-voltage test winding 2400 V				60 s			
Test	Torque [Nm]	Line U[V]	f[Hz]	Input I[A]	P1 [kW]	Output P2 [kW]	n[r/min]	cos φ	η [%]		
No load test		399,9 D	50	117,5	3,36		1000	0,04			
Locked rotor test		80,4 D	50	359,3	14,8		0	0,30			
Thermal test (100% load)	1923,0	400,1 D	50	364,5	209,9	200,0	992	0,83	95,3		
Partial load points:											
~75% load	1438,0	400,0 D	50	281,7	157,0	150,0	994	0,80	95,6		
~50% load	960,7	400,1 D	50	207,6	104,9	100,0	996	0,73	95,3		
~25% load	475,2	400,2 D	50	147,6	53,8	50,0	998	0,53	93,0		
Temperature rise at rated load.				°C	K	Method		Measurement method			
Stator winding :				64,9	1			1 Resistance			
Frame :				39,4	2			2 Thermometer			
Bearing D-end :				45,3	2			3 Thermocouples			
Rotor:				109,9	3						
Ambient Temperature :				25,0	2						
								Starting current (I _S / I _N) : 7,03			
								Locked rotor torque (T _L / T _N) : 2,72			
Manufactured and tested in accordance with rules of IEC 60034-1 and IEC 60034-2-1. PLL determined from residual loss.											
On behalf of customer											
On behalf of manufacturer			Date of test		1.2.2011						
Tested by ABB Oy, Motors and Generators, Vaasa, Finland							Telephone +358 10 2211				
							Telefax +358 10 22 47372				

Computer print-out valid without signature.