

CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN



NOTIFICATION OF TEST RESULTS

NTR/31074/IMQ

Product	Type F residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)
Tested by request of	ABB S.p.A. Via Vittor Pisani 16 20124 Milano (MI) – Italy
Manufactured at (name and place)	ABB S.p.A. Via Ardeatina 2491 00040 Santa Palomba (RM) – Italy
Preliminary visit carried out by	IMQ
Rating and principal characteristics	1P+N – Un = 230 V – Curve B or C In = 6, 10, 13, 16, 20, 25, 32 or 40 A type F – IΔn = 10 or 30 mA Icn = 10000 A – IΔm = 6000 A (see pages 4 and 6 of Test Report PB18-0031588-04-00)
Trade mark (if any)	ABB
Model/Type Ref.	Series DS201 M (see page 6 of Test Report PB18-0031588-04-00)
Additional information (if necessary)	THIS PRODUCT IS COVERED BY A LICENCE OF IMQ MARK IMQ APPROVAL CERTIFICATE No. CA03.00834 Testing location/procedure: CTF Stage 2
<i>A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)</i>	
<ul style="list-style-type: none">• EN 61008-1:2012 + A1:2014 + A2:2014 + A11:2015• EN 61008-2-1:1994 + A11:1998• EN 62423:2012	
as shown in the test reports (reference No.)	PB18-0031588-04-00, PB18-0031588-04-01, PB18-0031588-04-02, PB18-0031588-03-00 and from PB18-0031588-03-01 to PB18-0031588-03-32

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body which participates directly in the CENELEC Certification Agreement (CCA) of September 11th, 1973 as revised on March 29th, 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA.

IMQ S.p.A.

Milano, 2019-01-24

Signature of the authorized person _____

Name and function of the authorized person

Mauro Casari

**B.U. "Product Conformity Assessment"
"Project Management & Certification" Area
"Certification" Sector (voluntary field) - Manager**

Tel.: (+39) 02-50731

Fax.: (+39) 02-50991500

e-mail: info@imq.it