

产品认证证书

II型自愿认证

证书编号: CQC2018010304057354

发证日期: 2022年02月23日

有效期至: 2032年02月22日

委托人名称	ABB Stotz-Kontakt GmbH		
及注册地址	Eppelheimer Strasse 82 69123 Heidelberg Germany		
制造商名称	ABB Stotz-Kontakt GmbH		
及注册地址	Eppelheimer Strasse 82 69123 Heidelberg Germany		
生产企业名称	ABB Stotz-Kontakt GmbH		
及生产地址	Eppelheimer Strasse 82	69123 Heidelberg	Germany
产品名称和系列、规格、型号	接触器 ESB100-xxN; 参数及型号解释见附件		
产品标准和技术要求	GB/T 14048.4-2020		
认证模式	产品型式试验+初次工厂检查+获证后监督		

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年09月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

陈昕

签发

谢肇煦

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0132250

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2018010304057354

Valid from: Feb.23,2022

Valid until: Feb.22,2032

NAME AND REGISTERED ADDRESS OF THE APPLICANT ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND LOCATION OF THE FACTORY ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

PRODUCT NAME, MODEL AND SPECIFICATION Contactor
ESB100-xxN; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.4-2020

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.02,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦

CHINA QUALITY CERTIFICATION CENTRE



产品认证证书

II型自愿认证

附 录

证书编号: CQC2018010304057354

第 1 页 共 2 页

纸 号: 132250

ESB100-xxN

U_i : 500V;

U_{imp} : 6kV;

I_{th} : 100A;

ESB100-20N, ESB100-40N: AC-1: U_e/I_e : AC400V/100A;

ESB100-40N:

DC-1: U_e/I_e : DC24V/100A, DC48V/100A, DC60V/80A,

DC110V/50A, DC220V/35A;

DC-3: U_e/I_e : DC24V/100A, DC48V/70A, DC60V/45A,

DC110V/25A, DC220V/7A;

IP20;

极数: 2P, 4P;

配用的辅助触头: (EH04-11N, EH04-20N)

1NO1NC, 2NO

I_{th} : 6A;

AC-15: U_e/I_e : 120V/6A (NO/NC), 240V/4A (NO/NC),

415V/3A (NO/NC), 500V/2A (NO/NC)

注: 此附录与证书同时使用时有效。



中国质量认证中心



产品认证证书

II型自愿认证

附 录

证书编号: CQC2018010304057354

第 2 页 共 2 页

纸 号: 132250

型号解释:

Full type 型号		ESB100-40N-06							
		1 (ESB)	—	2 (100)	—	3 (40)	4 (N)	—	5 (06)
Position 位置	product 产品	√	√	√	√	√	√	√	
	package label 标签	√	√	√	√	√	√	√	√

1. Model name 接触器名称

ESB - standard model 标准型, 自动操作

EN - with additional manual operation 手动/自动操作

2. Basic type 100 基本型号

3. Contact variants of the contactor 主触点类型

40 4 NO 4 常开

20 2 NO 2 常开

4. ESB series suffix 工厂代号

Blank- standard version 空白 常规版

N - upgraded version N 升级版

5. Coil code 线圈代号

V ac/dc 电压	Coil type 线圈代号
24	01
230	06

注: 此附录与证书同时使用时有效。



中国质量认证中心

