

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO
ABB SOUTH AFRICA (PTY) LTD

IN TERMS OF SANS 10142 CLAUSE 4.
ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: EARTH LEAKAGE PROTECTION UNITS - ELCBs (ABB) FH202 AC, FH202 A;
 $U_n = 240V \sim 2P (1P+N)$; $I_n = 63A$; $I_{cn} = 6.0kA$; $I_{\Delta n} = 0.03A$; 50Hz;

Test Laboratory:
ZTME

Test report no: 1W181448

RCC No: 1904029

NRCS – Electrotechnical General Manager.



In accordance to(Standards):

VC8035:1987 + Amendment:1990

SABS 767-1:1982 + A1:1985 + A2:1997

Period of Validity

24/04/2019 to 24/04/2022

DATE 26/04/2019