

产品认证证书

II型自愿认证

证书编号: CQC2019010303150608

发证日期: 2021年06月17日

有效期至: 2024年01月16日

委托人名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

制造商名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称 ATM Electronics Ltd.
及生产地址 Varna Str.1 2850 Petrich Bulgaria

产品名称和系列、规格、型号 时间继电器
CT-MFD.xx,CT-ERD.xx,CT-AHD.xx,CT-VWD.xx,CT-EBD.xx,CT-TGD.xx,
CT-SDD.xx,CT-SAD.xx,CT-MFC.xx,CT-ERC.xx,CT-AHC.xx,CT-VWC.xx,
CT-TGC.xx,CT-SDC.xx, CT-SAC.xx,CT-MKC.xx, CT-ARC.xx,CT-EBC.xx, CT-PAC.22;Ui:300V;
Uimp:4kV;Ithe:5A ; AC-15:Ue/Ie:230V/3A,DC-13:Ue/Ie:24V/2A;CT-MKC:
AC-15:Ue/Ie:230V/0.25A,DC-13:Ue/Ie:24V/1A; IP20; 型号解释详见附件

产品标准和技术要求 GB/T 14048.5-2017

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年09月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕

陆楠

中国质量认证中心



CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010303150608

Valid from: Jun.17,2021

Valid until: Jan.16,2024

NAME AND REGISTERED ADDRESS OF THE APPLICANT ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND LOCATION OF THE FACTORY ATM Electronics Ltd.
Varna Str.1 2850 Petrich Bulgaria

PRODUCT NAME, MODEL AND SPECIFICATION Timedelay Relay
CT-MFD.xx,CT-ERD.xx,CT-AHD.xx,CT-VWD.xx,CT-EBD.xx,CT-TGD.xx,
CT-SDD.xx,CT-SAD.xx,CT-MFC.xx,CT-ERC.xx,CT-AHC.xx,CT-VWC.xx, CT-TGC.xx,CT-SDC.xx,
CT-SAC.xx,CT-MKC.xx, CT-ARC.xx,CT-EBC.xx, CT-PAC.22;Ui:300V; Uimp:4kV;Ithe:5A ;
AC-15:Ue/Ie:230V/3A,DC-13:Ue/Ie:24V/2A;CT-MKC:
AC-15:Ue/Ie:230V/0.25A,DC-13:Ue/Ie:24V/1A; IP20; See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.02,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠



CHINA QUALITY CERTIFICATION CENTRE



产品认证证书

II型自愿认证

证书编号: CQC2019010303150608

第 1 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号:

型号解释:

CT- I MFD. II 1 III 2 IV

I	Series / Type 系列/型号	CT-	Electronic timer relays 电子时间继电器
II	Variant 功能种类	MFD	Multifunction timer 多功能
		ERD	ON-delay timer 通电延时
		AHD	OFF-delay timer 断电延时
		VWD	Impulse ON timer 通电脉冲延时
		EBD	Flasher starting with ON 通电闪烁, 以 ON (亮态) 开始
		TGD	Pulse generator 脉冲发生器
		SDD	Star-delta timer 星三角转换
		SAD	Star-delta timer with adjustable transition time 星三角转换, 且转换时间可调
		MFC	Multifunction timer 多功能
		ERC	ON-delay timer 通电延时
		AHC	OFF-delay timer 断电延时
		VWC	Impulse ON timer 通电脉冲延时
		TGC	Pulse generator 脉冲发生器
		SDC	Star-delta timer 星三角转换
		SAC	Star-delta timer with adjustable transition time 星三角转换, 且转换时间可调
		EBC	Flasher starting with ON 通电闪烁, 以 ON (亮态) 开始
		MKC	Multifunction timer 多功能
		ARC	OFF-delay timer, without auxiliary voltage 断电延时, 无辅助电压



中国质量认证中心

产品认证证书

II型自愿认证

证书编号: CQC2019010303150608

第 2 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号:

		PAC	time relay ,alternating 输出触点交替导通
III	Relay-Outputs 继电器输出	1	1 C/O – Contact 1 C/O 触点
		2	2 C/O – Contact 2 C/O 触点
		3	1 N/O – Contact 1 N/O Solid-state output 1常开-触点固态输出
IV	Input / Supply Voltage 输入/供电电压	1	12...240V AC/DC
		2	24...48V DC / 24...240V AC



中国质量认证中心