

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Circuit breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the factory

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Additional Information on page 2

230/400 V a.c.;  
In = 0,2 ... 63 A; Characteristic B; C; D; K; Z  
Icu = 15 kA; Ics = 7,5 / 11,25 kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series SU200ML

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007  
IEC 60947-1:2007/AMD1:2010  
IEC 60947-1:2007/AMD2:2014  
IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

252675-TL3-1

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierung Produkte / Certification Products

Date: 2018-09-19

Signature:

J. Richter